

HYDRO PRESSURE TEST

TC No.: HPT/MOD5/CA/RQ/060/25	Model No.: KMCRQ-5	Date: 05-09-2025
Type and Capacity of Extinguisher	: KMCRQ-5-Kanex Clean Agent Modular HFC Based Fire Extinguisher Cap. 5 Kg.	
Batch Number	: KMCRQ5 060/25	
Batch Quantity	: 50.00 Nos.	
Serial Numbers	: 02951 To 3000	
Month of Manufacturing	: Sep/25	

Sr. Nos.	Result	Sr. Nos.	Result	Sr. Nos.	Result	Sr. Nos.	Result
Burst test conducted on 02951 To 3000 and removed from the Lot/Batch							
2951	Pass	2952	Pass	2953	Pass	2954	Pass
2955	Pass	2956	Pass	2957	Pass	2958	Pass
2959	Pass	2960	Pass	2961	Pass	2962	Pass
2963	Pass	2964	Pass	2965	Pass	2966	Pass
2967	Pass	2968	Pass	2969	Pass	2970	Pass
2971	Pass	2972	Pass	2973	Pass	2974	Pass
2975	Pass	2976	Pass	2977	Pass	2978	Pass
2979	Pass	2980	Pass	2981	Pass	2982	Pass
2983	Pass	2984	Pass	2985	Pass	2986	Pass
2987	Pass	2988	Pass	2989	Pass	2990	Pass
2991	Pass	2992	Pass	2993	Pass	2994	Pass
2995	Pass	2996	Pass	2997	Pass	2998	Pass
2999	Pass	3000	Pass				

Remarks: This is to certify that the above mentioned Fire Extinguishers are tested for hydraulic pressure of 35 bar for 2.5 minute and found satisfactory. No any leakage observed.



Authorized Signatory