

HYDRO PRESSURE TEST

TC No.: HPT/A2/A90/RQ/079/25	Model No.: KFARQ-2-90%	Date: 24-08-2025
Type and Capacity of Extinguisher	: KFARQ-2-90%-Kanex ABC Dry Powder Fire Extinguisher Cap. 2 Kg.	
Batch Number	: KFARQ90%2 079/25	
Batch Quantity	: 101.00 Nos.	
Serial Numbers	: 07801 To 7900 And 7805A	
Month of Manufacturing	: Aug/25	

Sr. Nos.	Result	Sr. Nos.	Result	Sr. Nos.	Result	Sr. Nos.	Result
Burst test conducted on 7805A and removed from the Lot/Batch							
7801	Pass	7802	Pass	7803	Pass	7804	Pass
7805	Pass	7806	Pass	7807	Pass	7808	Pass
7809	Pass	7810	Pass	7811	Pass	7812	Pass
7813	Pass	7814	Pass	7815	Pass	7816	Pass
7817	Pass	7818	Pass	7819	Pass	7820	Pass
7821	Pass	7822	Pass	7823	Pass	7824	Pass
7825	Pass	7826	Pass	7827	Pass	7828	Pass
7829	Pass	7830	Pass	7831	Pass	7832	Pass
7833	Pass	7834	Pass	7835	Pass	7836	Pass
7837	Pass	7838	Pass	7839	Pass	7840	Pass
7841	Pass	7842	Pass	7843	Pass	7844	Pass
7845	Pass	7846	Pass	7847	Pass	7848	Pass
7849	Pass	7850	Pass	7851	Pass	7852	Pass
7853	Pass	7854	Pass	7855	Pass	7856	Pass
7857	Pass	7858	Pass	7859	Pass	7860	Pass
7861	Pass	7862	Pass	7863	Pass	7864	Pass
7865	Pass	7866	Pass	7867	Pass	7868	Pass
7869	Pass	7870	Pass	7871	Pass	7872	Pass
7873	Pass	7874	Pass	7875	Pass	7876	Pass
7877	Pass	7878	Pass	7879	Pass	7880	Pass
7881	Pass	7882	Pass	7883	Pass	7884	Pass
7885	Pass	7886	Pass	7887	Pass	7888	Pass
7889	Pass	7890	Pass	7891	Pass	7892	Pass
7893	Pass	7894	Pass	7895	Pass	7896	Pass
7897	Pass	7898	Pass	7899	Pass	7900	Pass

Remarks: This is to certify that the above mentioned Fire Extinguishers are tested for hydraulic pressure of 35 bar for 2.5 minute and found satisfactory. No any leakage observed.



Authorized Signatory