

HYDRO PRESSURE TEST

TC No.: HPT/A6/A50/RQ/290/25	Model No.: KFARQ-6-50%	Date: 07-09-2025
Type and Capacity of Extinguisher	: KFARQ-6-50%-Kanex ABC Dry Powder Fire Extinguisher Cap. 6 Kg.	
Batch Number	: KFARQ50%6 290/25	
Batch Quantity	: 101.00 Nos.	
Serial Numbers	: 28901 To 29000 And 28905A	
Month of Manufacturing	: Sep/25	

Sr. Nos.	Result	Sr. Nos.	Result	Sr. Nos.	Result	Sr. Nos.	Result
Burst test conducted on 28905A and removed from the Lot/Batch							
28901	Pass	28902	Pass	28903	Pass	28904	Pass
28905	Pass	28906	Pass	28907	Pass	28908	Pass
28909	Pass	28910	Pass	28911	Pass	28912	Pass
28913	Pass	28914	Pass	28915	Pass	28916	Pass
28917	Pass	28918	Pass	28919	Pass	28920	Pass
28921	Pass	28922	Pass	28923	Pass	28924	Pass
28925	Pass	28926	Pass	28927	Pass	28928	Pass
28929	Pass	28930	Pass	28931	Pass	28932	Pass
28933	Pass	28934	Pass	28935	Pass	28936	Pass
28937	Pass	28938	Pass	28939	Pass	28940	Pass
28941	Pass	28942	Pass	28943	Pass	28944	Pass
28945	Pass	28946	Pass	28947	Pass	28948	Pass
28949	Pass	28950	Pass	28951	Pass	28952	Pass
28953	Pass	28954	Pass	28955	Pass	28956	Pass
28957	Pass	28958	Pass	28959	Pass	28960	Pass
28961	Pass	28962	Pass	28963	Pass	28964	Pass
28965	Pass	28966	Pass	28967	Pass	28968	Pass
28969	Pass	28970	Pass	28971	Pass	28972	Pass
28973	Pass	28974	Pass	28975	Pass	28976	Pass
28977	Pass	28978	Pass	28979	Pass	28980	Pass
28981	Pass	28982	Pass	28983	Pass	28984	Pass
28985	Pass	28986	Pass	28987	Pass	28988	Pass
28989	Pass	28990	Pass	28991	Pass	28992	Pass
28993	Pass	28994	Pass	28995	Pass	28996	Pass
28997	Pass	28998	Pass	28999	Pass	29000	Pass

Remarks: This is to certify that the above mentioned Fire Extinguishers are tested for hydraulic pressure of 35 bar for 2.5 minute and found satisfactory. No any leakage observed.



Authorized Signatory