

HYDRO PRESSURE TEST

TC No.: HPT/A6/A50/RQ/291/25	Model No.: KFARQ-6-50%	Date: 07-09-2025
Type and Capacity of Extinguisher	: KFARQ-6-50%-Kanex ABC Dry Powder Fire Extinguisher Cap. 6 Kg.	
Batch Number	: KFARQ50%6 291/25	
Batch Quantity	: 101.00 Nos.	
Serial Numbers	: 29001 To 29100 And 29005A	
Month of Manufacturing	: Sep/25	

Sr. Nos.	Result	Sr. Nos.	Result	Sr. Nos.	Result	Sr. Nos.	Result
Burst test conducted on 29005A and removed from the Lot/Batch							
29001	Pass	29002	Pass	29003	Pass	29004	Pass
29005	Pass	29006	Pass	29007	Pass	29008	Pass
29009	Pass	29010	Pass	29011	Pass	29012	Pass
29013	Pass	29014	Pass	29015	Pass	29016	Pass
29017	Pass	29018	Pass	29019	Pass	29020	Pass
29021	Pass	29022	Pass	29023	Pass	29024	Pass
29025	Pass	29026	Pass	29027	Pass	29028	Pass
29029	Pass	29030	Pass	29031	Pass	29032	Pass
29033	Pass	29034	Pass	29035	Pass	29036	Pass
29037	Pass	29038	Pass	29039	Pass	29040	Pass
29041	Pass	29042	Pass	29043	Pass	29044	Pass
29045	Pass	29046	Pass	29047	Pass	29048	Pass
29049	Pass	29050	Pass	29051	Pass	29052	Pass
29053	Pass	29054	Pass	29055	Pass	29056	Pass
29057	Pass	29058	Pass	29059	Pass	29060	Pass
29061	Pass	29062	Pass	29063	Pass	29064	Pass
29065	Pass	29066	Pass	29067	Pass	29068	Pass
29069	Pass	29070	Pass	29071	Pass	29072	Pass
29073	Pass	29074	Pass	29075	Pass	29076	Pass
29077	Pass	29078	Pass	29079	Pass	29080	Pass
29081	Pass	29082	Pass	29083	Pass	29084	Pass
29085	Pass	29086	Pass	29087	Pass	29088	Pass
29089	Pass	29090	Pass	29091	Pass	29092	Pass
29093	Pass	29094	Pass	29095	Pass	29096	Pass
29097	Pass	29098	Pass	29099	Pass	29100	Pass

Remarks: This is to certify that the above mentioned Fire Extinguishers are tested for hydraulic pressure of 35 bar for 2.5 minute and found satisfactory. No any leakage observed.



Authorized Signatory