

HYDRO PRESSURE TEST

TC No.: HPT/A6/A50/RQ/292/25	Model No.: KFARQ-6-50%	Date: 07-09-2025
Type and Capacity of Extinguisher	: KFARQ-6-50%-Kanex ABC Dry Powder Fire Extinguisher Cap. 6 Kg.	
Batch Number	: KFARQ50%6 292/25	
Batch Quantity	: 101.00 Nos.	
Serial Numbers	: 29101 To 29200 And 29105A	
Month of Manufacturing	: Sep/25	

Sr. Nos.	Result	Sr. Nos.	Result	Sr. Nos.	Result	Sr. Nos.	Result
Burst test conducted on 29105A and removed from the Lot/Batch							
29101	Pass	29102	Pass	29103	Pass	29104	Pass
29105	Pass	29106	Pass	29107	Pass	29108	Pass
29109	Pass	29110	Pass	29111	Pass	29112	Pass
29113	Pass	29114	Pass	29115	Pass	29116	Pass
29117	Pass	29118	Pass	29119	Pass	29120	Pass
29121	Pass	29122	Pass	29123	Pass	29124	Pass
29125	Pass	29126	Pass	29127	Pass	29128	Pass
29129	Pass	29130	Pass	29131	Pass	29132	Pass
29133	Pass	29134	Pass	29135	Pass	29136	Pass
29137	Pass	29138	Pass	29139	Pass	29140	Pass
29141	Pass	29142	Pass	29143	Pass	29144	Pass
29145	Pass	29146	Pass	29147	Pass	29148	Pass
29149	Pass	29150	Pass	29151	Pass	29152	Pass
29153	Pass	29154	Pass	29155	Pass	29156	Pass
29157	Pass	29158	Pass	29159	Pass	29160	Pass
29161	Pass	29162	Pass	29163	Pass	29164	Pass
29165	Pass	29166	Pass	29167	Pass	29168	Pass
29169	Pass	29170	Pass	29171	Pass	29172	Pass
29173	Pass	29174	Pass	29175	Pass	29176	Pass
29177	Pass	29178	Pass	29179	Pass	29180	Pass
29181	Pass	29182	Pass	29183	Pass	29184	Pass
29185	Pass	29186	Pass	29187	Pass	29188	Pass
29189	Pass	29190	Pass	29191	Pass	29192	Pass
29193	Pass	29194	Pass	29195	Pass	29196	Pass
29197	Pass	29198	Pass	29199	Pass	29200	Pass

Remarks: This is to certify that the above mentioned Fire Extinguishers are tested for hydraulic pressure of 35 bar for 2.5 minute and found satisfactory. No any leakage observed.



Authorized Signatory