

HYDRO PRESSURE TEST

TC No.: HPT/A6/A50/RQ/293/25	Model No.: KFARQ-6-50%	Date: 07-09-2025
Type and Capacity of Extinguisher	: KFARQ-6-50%-Kanex ABC Dry Powder Fire Extinguisher Cap. 6 Kg.	
Batch Number	: KFARQ50%6 293/25	
Batch Quantity	: 101.00 Nos.	
Serial Numbers	: 29201 To 29300 And 29205A	
Month of Manufacturing	: Sep/25	

Sr. Nos.	Result	Sr. Nos.	Result	Sr. Nos.	Result	Sr. Nos.	Result
Burst test conducted on 29205A and removed from the Lot/Batch							
29201	Pass	29202	Pass	29203	Pass	29204	Pass
29205	Pass	29206	Pass	29207	Pass	29208	Pass
29209	Pass	29210	Pass	29211	Pass	29212	Pass
29213	Pass	29214	Pass	29215	Pass	29216	Pass
29217	Pass	29218	Pass	29219	Pass	29220	Pass
29221	Pass	29222	Pass	29223	Pass	29224	Pass
29225	Pass	29226	Pass	29227	Pass	29228	Pass
29229	Pass	29230	Pass	29231	Pass	29232	Pass
29233	Pass	29234	Pass	29235	Pass	29236	Pass
29237	Pass	29238	Pass	29239	Pass	29240	Pass
29241	Pass	29242	Pass	29243	Pass	29244	Pass
29245	Pass	29246	Pass	29247	Pass	29248	Pass
29249	Pass	29250	Pass	29251	Pass	29252	Pass
29253	Pass	29254	Pass	29255	Pass	29256	Pass
29257	Pass	29258	Pass	29259	Pass	29260	Pass
29261	Pass	29262	Pass	29263	Pass	29264	Pass
29265	Pass	29266	Pass	29267	Pass	29268	Pass
29269	Pass	29270	Pass	29271	Pass	29272	Pass
29273	Pass	29274	Pass	29275	Pass	29276	Pass
29277	Pass	29278	Pass	29279	Pass	29280	Pass
29281	Pass	29282	Pass	29283	Pass	29284	Pass
29285	Pass	29286	Pass	29287	Pass	29288	Pass
29289	Pass	29290	Pass	29291	Pass	29292	Pass
29293	Pass	29294	Pass	29295	Pass	29296	Pass
29297	Pass	29298	Pass	29299	Pass	29300	Pass

Remarks: This is to certify that the above mentioned Fire Extinguishers are tested for hydraulic pressure of 35 bar for 2.5 minute and found satisfactory. No any leakage observed.



Authorized Signatory