

HYDRO PRESSURE TEST

TC No.: HPT/CA6/RQ/007/25	Model No.: KCARQ-6	Date: 10-06-2025
Type and Capacity of Extinguisher	: KCARQ-6-Kanex Clean Agent HFC Based Fire Extinguisher Cap. 6 Kg.	
Batch Number	: KCARQ6 007/25	
Batch Quantity	: 101.00 Nos.	
Serial Numbers	: 00601 To 700 And 605A	
Month of Manufacturing	: Jun/25	

Sr. Nos.	Result	Sr. Nos.	Result	Sr. Nos.	Result	Sr. Nos.	Result
Burst test conducted on 605A and removed from the Lot/Batch							
601	Pass	602	Pass	603	Pass	604	Pass
605	Pass	606	Pass	607	Pass	608	Pass
609	Pass	610	Pass	611	Pass	612	Pass
613	Pass	614	Pass	615	Pass	616	Pass
617	Pass	618	Pass	619	Pass	620	Pass
621	Pass	622	Pass	623	Pass	624	Pass
625	Pass	626	Pass	627	Pass	628	Pass
629	Pass	630	Pass	631	Pass	632	Pass
633	Pass	634	Pass	635	Pass	636	Pass
637	Pass	638	Pass	639	Pass	640	Pass
641	Pass	642	Pass	643	Pass	644	Pass
645	Pass	646	Pass	647	Pass	648	Pass
649	Pass	650	Pass	651	Pass	652	Pass
653	Pass	654	Pass	655	Pass	656	Pass
657	Pass	658	Pass	659	Pass	660	Pass
661	Pass	662	Pass	663	Pass	664	Pass
665	Pass	666	Pass	667	Pass	668	Pass
669	Pass	670	Pass	671	Pass	672	Pass
673	Pass	674	Pass	675	Pass	676	Pass
677	Pass	678	Pass	679	Pass	680	Pass
681	Pass	682	Pass	683	Pass	684	Pass
685	Pass	686	Pass	687	Pass	688	Pass
689	Pass	690	Pass	691	Pass	692	Pass
693	Pass	694	Pass	695	Pass	696	Pass
697	Pass	698	Pass	699	Pass	700	Pass

Remarks: This is to certify that the above mentioned Fire Extinguishers are tested for hydraulic pressure of 35 bar for 2.5 minute and found satisfactory. No any leakage observed.



Authorized Signatory