

HYDRO PRESSURE TEST

TC No.: HPT/MOD5/CA/RQ/066/25	Model No.: KMCRQ-5	Date: 26-09-2025
Type and Capacity of Extinguisher	: KMCRQ-5-Kanex Clean Agent Modular HFC Based Fire Extinguisher Cap. 5 Kg.	
Batch Number	: KMCRQ5 066/25	
Batch Quantity	: 50.00 Nos.	
Serial Numbers	: 03251 To 3300	
Month of Manufacturing	: Sep/25	

Sr. Nos.	Result	Sr. Nos.	Result	Sr. Nos.	Result	Sr. Nos.	Result
Burst test conducted on 03251 To 3300 and removed from the Lot/Batch							
3251	Pass	3252	Pass	3253	Pass	3254	Pass
3255	Pass	3256	Pass	3257	Pass	3258	Pass
3259	Pass	3260	Pass	3261	Pass	3262	Pass
3263	Pass	3264	Pass	3265	Pass	3266	Pass
3267	Pass	3268	Pass	3269	Pass	3270	Pass
3271	Pass	3272	Pass	3273	Pass	3274	Pass
3275	Pass	3276	Pass	3277	Pass	3278	Pass
3279	Pass	3280	Pass	3281	Pass	3282	Pass
3283	Pass	3284	Pass	3285	Pass	3286	Pass
3287	Pass	3288	Pass	3289	Pass	3290	Pass
3291	Pass	3292	Pass	3293	Pass	3294	Pass
3295	Pass	3296	Pass	3297	Pass	3298	Pass
3299	Pass	3300	Pass				

Remarks: This is to certify that the above mentioned Fire Extinguishers are tested for hydraulic pressure of 35 bar for 2.5 minute and found satisfactory. No any leakage observed.



Authorized Signatory