

HYDRO PRESSURE TEST

TC No.: HPT/A6/A50/RQ/332/25	Model No.: KFARQ-6-50%	Date: 17-11-2025
Type and Capacity of Extinguisher	: KFARQ-6-50%-Kanex ABC Dry Powder Fire Extinguisher Cap. 6 Kg.	
Batch Number	: KFARQ50%6 332/25	
Batch Quantity	: 101.00 Nos.	
Serial Numbers	: 33101 To 33200 And 33105A	
Month of Manufacturing	: Nov/25	

Sr. Nos.	Result	Sr. Nos.	Result	Sr. Nos.	Result	Sr. Nos.	Result
Burst test conducted on 33105A and removed from the Lot/Batch							
33101	Pass	33102	Pass	33103	Pass	33104	Pass
33105	Pass	33106	Pass	33107	Pass	33108	Pass
33109	Pass	33110	Pass	33111	Pass	33112	Pass
33113	Pass	33114	Pass	33115	Pass	33116	Pass
33117	Pass	33118	Pass	33119	Pass	33120	Pass
33121	Pass	33122	Pass	33123	Pass	33124	Pass
33125	Pass	33126	Pass	33127	Pass	33128	Pass
33129	Pass	33130	Pass	33131	Pass	33132	Pass
33133	Pass	33134	Pass	33135	Pass	33136	Pass
33137	Pass	33138	Pass	33139	Pass	33140	Pass
33141	Pass	33142	Pass	33143	Pass	33144	Pass
33145	Pass	33146	Pass	33147	Pass	33148	Pass
33149	Pass	33150	Pass	33151	Pass	33152	Pass
33153	Pass	33154	Pass	33155	Pass	33156	Pass
33157	Pass	33158	Pass	33159	Pass	33160	Pass
33161	Pass	33162	Pass	33163	Pass	33164	Pass
33165	Pass	33166	Pass	33167	Pass	33168	Pass
33169	Pass	33170	Pass	33171	Pass	33172	Pass
33173	Pass	33174	Pass	33175	Pass	33176	Pass
33177	Pass	33178	Pass	33179	Pass	33180	Pass
33181	Pass	33182	Pass	33183	Pass	33184	Pass
33185	Pass	33186	Pass	33187	Pass	33188	Pass
33189	Pass	33190	Pass	33191	Pass	33192	Pass
33193	Pass	33194	Pass	33195	Pass	33196	Pass
33197	Pass	33198	Pass	33199	Pass	33200	Pass

Remarks: This is to certify that the above mentioned Fire Extinguishers are tested for hydraulic pressure of 35 bar for 2.5 minute and found satisfactory. No any leakage observed.



Authorized Signatory