

HYDRO PRESSURE TEST

TC No.: HPT/MOD10/CA/FK/RQ/038/25	Model No.: KMCRQ-10-FK	Date: 03-11-2025
Type and Capacity of Extinguisher	: KMCRQ-10-FK-Kanex Clean Agent Modular FK5112 Based Fire Extinguisher Cap.	
Batch Number	: KMCRQ10FK 038/25	
Batch Quantity	: 10.00 Nos.	
Serial Numbers	: 00371 To 380	
Month of Manufacturing	: Nov/25	

Sr. Nos.	Result	Sr. Nos.	Result	Sr. Nos.	Result	Sr. Nos.	Result
Burst test conducted on 00371 To 380 and removed from the Lot/Batch							
371	Pass	372	Pass	373	Pass	374	Pass
375	Pass	376	Pass	377	Pass	378	Pass
379	Pass	380	Pass				

Remarks: This is to certify that the above mentioned Fire Extinguishers are tested for hydraulic pressure of 35 bar for 2.5 minute and found satisfactory. No any leakage observed



Authorized Signatory