

HYDRO PRESSURE TEST

TC No.: HPT/MA6/A40/RQ/327/25	Model No.: MARQ-6-50%	Date: 16-11-2025
Type and Capacity of Extinguisher	: MARQ-6-50%-Kanex ABC Dry Powder Fire Extinguisher Cap. 6 Kg.	
Batch Number	: MARQ50%6 327/25	
Batch Quantity	: 101.00 Nos.	
Serial Numbers	: 32601 To 32700 And 32605A	
Month of Manufacturing	: Nov/25	

Sr. Nos.	Result	Sr. Nos.	Result	Sr. Nos.	Result	Sr. Nos.	Result
Burst test conducted on 32605A and removed from the Lot/Batch							
32601	Pass	32602	Pass	32603	Pass	32604	Pass
32605	Pass	32606	Pass	32607	Pass	32608	Pass
32609	Pass	32610	Pass	32611	Pass	32612	Pass
32613	Pass	32614	Pass	32615	Pass	32616	Pass
32617	Pass	32618	Pass	32619	Pass	32620	Pass
32621	Pass	32622	Pass	32623	Pass	32624	Pass
32625	Pass	32626	Pass	32627	Pass	32628	Pass
32629	Pass	32630	Pass	32631	Pass	32632	Pass
32633	Pass	32634	Pass	32635	Pass	32636	Pass
32637	Pass	32638	Pass	32639	Pass	32640	Pass
32641	Pass	32642	Pass	32643	Pass	32644	Pass
32645	Pass	32646	Pass	32647	Pass	32648	Pass
32649	Pass	32650	Pass	32651	Pass	32652	Pass
32653	Pass	32654	Pass	32655	Pass	32656	Pass
32657	Pass	32658	Pass	32659	Pass	32660	Pass
32661	Pass	32662	Pass	32663	Pass	32664	Pass
32665	Pass	32666	Pass	32667	Pass	32668	Pass
32669	Pass	32670	Pass	32671	Pass	32672	Pass
32673	Pass	32674	Pass	32675	Pass	32676	Pass
32677	Pass	32678	Pass	32679	Pass	32680	Pass
32681	Pass	32682	Pass	32683	Pass	32684	Pass
32685	Pass	32686	Pass	32687	Pass	32688	Pass
32689	Pass	32690	Pass	32691	Pass	32692	Pass
32693	Pass	32694	Pass	32695	Pass	32696	Pass
32697	Pass	32698	Pass	32699	Pass	32700	Pass

Remarks: This is to certify that the above mentioned Fire Extinguishers are tested for hydraulic pressure of 35 bar for 2.5 minute and found satisfactory. No any leakage observed.



Authorized Signatory