

HYDRO PRESSURE TEST

TC No.: HPT/MA6/A40/RQ/328/25	Model No.: MARQ-6-50%	Date: 17-11-2025
Type and Capacity of Extinguisher	: MARQ-6-50%-Kanex ABC Dry Powder Fire Extinguisher Cap. 6 Kg.	
Batch Number	: MARQ50%6 328/25	
Batch Quantity	: 101.00 Nos.	
Serial Numbers	: 32701 To 32800 And 32705A	
Month of Manufacturing	: Nov/25	

Sr. Nos.	Result	Sr. Nos.	Result	Sr. Nos.	Result	Sr. Nos.	Result
Burst test conducted on 32705A and removed from the Lot/Batch							
32701	Pass	32702	Pass	32703	Pass	32704	Pass
32705	Pass	32706	Pass	32707	Pass	32708	Pass
32709	Pass	32710	Pass	32711	Pass	32712	Pass
32713	Pass	32714	Pass	32715	Pass	32716	Pass
32717	Pass	32718	Pass	32719	Pass	32720	Pass
32721	Pass	32722	Pass	32723	Pass	32724	Pass
32725	Pass	32726	Pass	32727	Pass	32728	Pass
32729	Pass	32730	Pass	32731	Pass	32732	Pass
32733	Pass	32734	Pass	32735	Pass	32736	Pass
32737	Pass	32738	Pass	32739	Pass	32740	Pass
32741	Pass	32742	Pass	32743	Pass	32744	Pass
32745	Pass	32746	Pass	32747	Pass	32748	Pass
32749	Pass	32750	Pass	32751	Pass	32752	Pass
32753	Pass	32754	Pass	32755	Pass	32756	Pass
32757	Pass	32758	Pass	32759	Pass	32760	Pass
32761	Pass	32762	Pass	32763	Pass	32764	Pass
32765	Pass	32766	Pass	32767	Pass	32768	Pass
32769	Pass	32770	Pass	32771	Pass	32772	Pass
32773	Pass	32774	Pass	32775	Pass	32776	Pass
32777	Pass	32778	Pass	32779	Pass	32780	Pass
32781	Pass	32782	Pass	32783	Pass	32784	Pass
32785	Pass	32786	Pass	32787	Pass	32788	Pass
32789	Pass	32790	Pass	32791	Pass	32792	Pass
32793	Pass	32794	Pass	32795	Pass	32796	Pass
32797	Pass	32798	Pass	32799	Pass	32800	Pass

Remarks: This is to certify that the above mentioned Fire Extinguishers are tested for hydraulic pressure of 35 bar for 2.5 minute and found satisfactory. No any leakage observed.



Authorized Signatory