

HYDRO PRESSURE TEST

TC No.: HPT/MA6/A40/RQ/329/25	Model No.: MARQ-6-50%	Date: 17-11-2025
Type and Capacity of Extinguisher	: MARQ-6-50%-Kanex ABC Dry Powder Fire Extinguisher Cap. 6 Kg.	
Batch Number	: MARQ50%6 329/25	
Batch Quantity	: 101.00 Nos.	
Serial Numbers	: 32801 To 32900 And 32805A	
Month of Manufacturing	: Nov/25	

Sr. Nos.	Result	Sr. Nos.	Result	Sr. Nos.	Result	Sr. Nos.	Result
Burst test conducted on 32805A and removed from the Lot/Batch							
32801	Pass	32802	Pass	32803	Pass	32804	Pass
32805	Pass	32806	Pass	32807	Pass	32808	Pass
32809	Pass	32810	Pass	32811	Pass	32812	Pass
32813	Pass	32814	Pass	32815	Pass	32816	Pass
32817	Pass	32818	Pass	32819	Pass	32820	Pass
32821	Pass	32822	Pass	32823	Pass	32824	Pass
32825	Pass	32826	Pass	32827	Pass	32828	Pass
32829	Pass	32830	Pass	32831	Pass	32832	Pass
32833	Pass	32834	Pass	32835	Pass	32836	Pass
32837	Pass	32838	Pass	32839	Pass	32840	Pass
32841	Pass	32842	Pass	32843	Pass	32844	Pass
32845	Pass	32846	Pass	32847	Pass	32848	Pass
32849	Pass	32850	Pass	32851	Pass	32852	Pass
32853	Pass	32854	Pass	32855	Pass	32856	Pass
32857	Pass	32858	Pass	32859	Pass	32860	Pass
32861	Pass	32862	Pass	32863	Pass	32864	Pass
32865	Pass	32866	Pass	32867	Pass	32868	Pass
32869	Pass	32870	Pass	32871	Pass	32872	Pass
32873	Pass	32874	Pass	32875	Pass	32876	Pass
32877	Pass	32878	Pass	32879	Pass	32880	Pass
32881	Pass	32882	Pass	32883	Pass	32884	Pass
32885	Pass	32886	Pass	32887	Pass	32888	Pass
32889	Pass	32890	Pass	32891	Pass	32892	Pass
32893	Pass	32894	Pass	32895	Pass	32896	Pass
32897	Pass	32898	Pass	32899	Pass	32900	Pass

Remarks: This is to certify that the above mentioned Fire Extinguishers are tested for hydraulic pressure of 35 bar for 2.5 minute and found satisfactory. No any leakage observed.



Authorized Signatory