

HYDRO PRESSURE TEST

TC No.: HPT/A6/A50/RQ/331/25	Model No.: KFARQ-6-50%	Date: 17-11-2025
Type and Capacity of Extinguisher	: KFARQ-6-50%-Kanex ABC Dry Powder Fire Extinguisher Cap. 6 Kg.	
Batch Number	: KFARQ50%6 331/25	
Batch Quantity	: 101.00 Nos.	
Serial Numbers	: 33001 To 33100 And 33005A	
Month of Manufacturing	: Nov/25	

Sr. Nos.	Result	Sr. Nos.	Result	Sr. Nos.	Result	Sr. Nos.	Result
Burst test conducted on 33005A and removed from the Lot/Batch							
33001	Pass	33002	Pass	33003	Pass	33004	Pass
33005	Pass	33006	Pass	33007	Pass	33008	Pass
33009	Pass	33010	Pass	33011	Pass	33012	Pass
33013	Pass	33014	Pass	33015	Pass	33016	Pass
33017	Pass	33018	Pass	33019	Pass	33020	Pass
33021	Pass	33022	Pass	33023	Pass	33024	Pass
33025	Pass	33026	Pass	33027	Pass	33028	Pass
33029	Pass	33030	Pass	33031	Pass	33032	Pass
33033	Pass	33034	Pass	33035	Pass	33036	Pass
33037	Pass	33038	Pass	33039	Pass	33040	Pass
33041	Pass	33042	Pass	33043	Pass	33044	Pass
33045	Pass	33046	Pass	33047	Pass	33048	Pass
33049	Pass	33050	Pass	33051	Pass	33052	Pass
33053	Pass	33054	Pass	33055	Pass	33056	Pass
33057	Pass	33058	Pass	33059	Pass	33060	Pass
33061	Pass	33062	Pass	33063	Pass	33064	Pass
33065	Pass	33066	Pass	33067	Pass	33068	Pass
33069	Pass	33070	Pass	33071	Pass	33072	Pass
33073	Pass	33074	Pass	33075	Pass	33076	Pass
33077	Pass	33078	Pass	33079	Pass	33080	Pass
33081	Pass	33082	Pass	33083	Pass	33084	Pass
33085	Pass	33086	Pass	33087	Pass	33088	Pass
33089	Pass	33090	Pass	33091	Pass	33092	Pass
33093	Pass	33094	Pass	33095	Pass	33096	Pass
33097	Pass	33098	Pass	33099	Pass	33100	Pass

Remarks: This is to certify that the above mentioned Fire Extinguishers are tested for hydraulic pressure of 35 bar for 2.5 minute and found satisfactory. No any leakage observed.



Authorized Signatory