



# Warranty Certificate

**Date:** 09-12-2025

**Manufacturer:** Kanex Fire Solutions Limited.

**Customer Name:** Infiniti Building Solutions Pvt. Ltd.

**Warranty Start Date:** 09-12-2025

**Warranty End Date:** 08-12-2026.

This is to certify that the below extinguishers are warranted for a period of **1** year from the date of supply against any of Manufacturing/Quality defects.

**NOTE – IF TAMPER SEAL IS NOT INTACT, THE WARRANTY SHALL BE CONSIDERED VOID.**

| Sr.No. | Type & Capacity of Extinguishers                                 | Quantity | Sr. Nos.            |
|--------|------------------------------------------------------------------|----------|---------------------|
| 1      | KFCRQ-4.5-Kanex CO2 High Pressure Fire Extinguisher Cap. 4.5 Kg. | 4        | As Per Annexure – I |

Also certify that, all the Fire extinguishers supplied against Invoice No. **25-26/B/000183 Dated: 09-12-2025 P.O.No. IBSPL-PO-2526-2286** are hydraulically tested 100% at 35 bar except CO2 and randomly tested for performance test. All the extinguishers confirms to IS 15683:2018 (Portable) or IS 16018:2012 (Mobile) requirements.

Note : If applicable CO2 Cylinders are PESO approved & HPT tested at 225 bar by Cylinder Manufacturer.



**Authorized Signatory**