

# HYDRO PRESSURE TEST

|                                   |                                                                 |                  |
|-----------------------------------|-----------------------------------------------------------------|------------------|
| TC No.: HPT/A4/A50/RQ/031/25      | Model No.: KFARQ-4-50%                                          | Date: 21-04-2025 |
| Type and Capacity of Extinguisher | : KFARQ-4-50%-Kanex ABC Dry Powder Fire Extinguisher Cap. 4 Kg. |                  |
| Batch Number                      | : KFARQ50%4 031/25                                              |                  |
| Batch Quantity                    | : 101.00 Nos.                                                   |                  |
| Serial Numbers                    | : 03001 To 3100 And 3005A                                       |                  |
| Month of Manufacturing            | : Apr/25                                                        |                  |

| Sr. Nos.                                                     | Result | Sr. Nos. | Result | Sr. Nos. | Result | Sr. Nos. | Result |
|--------------------------------------------------------------|--------|----------|--------|----------|--------|----------|--------|
| Burst test conducted on 3005A and removed from the Lot/Batch |        |          |        |          |        |          |        |
| 3001                                                         | Pass   | 3002     | Pass   | 3003     | Pass   | 3004     | Pass   |
| 3005                                                         | Pass   | 3006     | Pass   | 3007     | Pass   | 3008     | Pass   |
| 3009                                                         | Pass   | 3010     | Pass   | 3011     | Pass   | 3012     | Pass   |
| 3013                                                         | Pass   | 3014     | Pass   | 3015     | Pass   | 3016     | Pass   |
| 3017                                                         | Pass   | 3018     | Pass   | 3019     | Pass   | 3020     | Pass   |
| 3021                                                         | Pass   | 3022     | Pass   | 3023     | Pass   | 3024     | Pass   |
| 3025                                                         | Pass   | 3026     | Pass   | 3027     | Pass   | 3028     | Pass   |
| 3029                                                         | Pass   | 3030     | Pass   | 3031     | Pass   | 3032     | Pass   |
| 3033                                                         | Pass   | 3034     | Pass   | 3035     | Pass   | 3036     | Pass   |
| 3037                                                         | Pass   | 3038     | Pass   | 3039     | Pass   | 3040     | Pass   |
| 3041                                                         | Pass   | 3042     | Pass   | 3043     | Pass   | 3044     | Pass   |
| 3045                                                         | Pass   | 3046     | Pass   | 3047     | Pass   | 3048     | Pass   |
| 3049                                                         | Pass   | 3050     | Pass   | 3051     | Pass   | 3052     | Pass   |
| 3053                                                         | Pass   | 3054     | Pass   | 3055     | Pass   | 3056     | Pass   |
| 3057                                                         | Pass   | 3058     | Pass   | 3059     | Pass   | 3060     | Pass   |
| 3061                                                         | Pass   | 3062     | Pass   | 3063     | Pass   | 3064     | Pass   |
| 3065                                                         | Pass   | 3066     | Pass   | 3067     | Pass   | 3068     | Pass   |
| 3069                                                         | Pass   | 3070     | Pass   | 3071     | Pass   | 3072     | Pass   |
| 3073                                                         | Pass   | 3074     | Pass   | 3075     | Pass   | 3076     | Pass   |
| 3077                                                         | Pass   | 3078     | Pass   | 3079     | Pass   | 3080     | Pass   |
| 3081                                                         | Pass   | 3082     | Pass   | 3083     | Pass   | 3084     | Pass   |
| 3085                                                         | Pass   | 3086     | Pass   | 3087     | Pass   | 3088     | Pass   |
| 3089                                                         | Pass   | 3090     | Pass   | 3091     | Pass   | 3092     | Pass   |
| 3093                                                         | Pass   | 3094     | Pass   | 3095     | Pass   | 3096     | Pass   |
| 3097                                                         | Pass   | 3098     | Pass   | 3099     | Pass   | 3100     | Pass   |

**Remarks: This is to certify that the above mentioned Fire Extinguishers are tested for hydraulic pressure of 35 bar for 2.5 minute and found satisfactory. No any leakage observed.**



**Authorized Signatory**