

QMF01	Declaration of Conformity DoC	    Assessed to ISO 9001 Cert/LPCB ref No 085 Cert No FM 59294
Doc Page No: 1 of 1		
Revision: 3		
Issue Date: 22/08/2023		
Authorised By: T.Swadzba		

Bailey & Mackey Ltd

Pressure Switch, Pressure Gauge and
Pressure Transducer Manufacture
Baltimore Road, Birmingham, B42 1DE
Tel: 0121 357 5351
Fax: 0121 357 8319
E-mail: enquiries@baileymackey.com
Registered in England No. 2140400

Declaration of Conformance

Customer:

KANEX FIRE SOLUTIONS LIM
PLOT NO 7 PARAS INDUSTRIAL ESTATE
NEAR GARIBSHA PIR DARGAH
SIHOR 364240
GUJARAT
INDIA

JOB No: 00E7929 ENTERED: 09/12/24 YOUR ORDER No: 14357

SPEC: AS DESCRIPTION QTY: 2000

SERIAL No: 25E7929 0001 to 25E7929 2000 inclusive.

DESCRIPTION

TYPE 12 P. SWITCH, RANGE 5/35 bar.
BRASS BASE Be. Cu. DIAPHRAGM, EPDM SEAL
CONNECTION M10x1 C/W Z080E SINTERED FILTER
IN PRESSURE PASSAGE TO DRG K601P
SPDT MICRO SWITCH RATED 5A 250V 50HZ
C/W 0.5M 4 CORE CABLE
BROWN/ BLACK/ GREY/ EARTH
FITTED WITH HEX GRUB SCREW.
INTERNAL ADJUSTER
SET AT 5 BAR FALLING
MANUFACTURED IN ACCORDANCE TO S.E.P. REF PED – 2014/68/EC
CE MARKED IN ACCORDANCE WITH THE LOW VOLTAGE DIRECTIVE 2014/35/EU

CERTIFIED THAT THE WHOLE OF THE SUPPLIES DETAILED HEREON HAVE BEEN INSPECTED, TESTED AND UNLESS OTHERWISE STATED CONFORM IN ALL RESPECTS WITH DETAILS OF THE CONTRACT OR ORDER AS DETAILED HERewith.

ALL TEST EQUIPMENT USED IN CONNECTION WITH THIS ORDER IS CERTIFIED TRACEABLE TO NATIONAL STANDARDS IN ACCORDANCE WITH REQUIREMENTS BS EN ISO 9001:2015

SIGNED: P Bolstridge POSITION: Q/A Department DATE: 25/02/25