

HYDRO PRESSURE TEST

TC No.: HPT/A6/A90/RQ/289/25	Model No.: KFARQ-6-90%	Date: 14-12-2025
Type and Capacity of Extinguisher	: KFARQ-6-90%-Kanex ABC Dry Powder Fire Extinguisher Cap. 6 Kg.	
Batch Number	: KFARQ90%6 289/25	
Batch Quantity	: 101.00 Nos.	
Serial Numbers	: 28801 To 28900 And 28805A	
Month of Manufacturing	: Dec/25	

Sr. Nos.	Result	Sr. Nos.	Result	Sr. Nos.	Result	Sr. Nos.	Result
Burst test conducted on 28805A and removed from the Lot/Batch							
28801	Pass	28802	Pass	28803	Pass	28804	Pass
28805	Pass	28806	Pass	28807	Pass	28808	Pass
28809	Pass	28810	Pass	28811	Pass	28812	Pass
28813	Pass	28814	Pass	28815	Pass	28816	Pass
28817	Pass	28818	Pass	28819	Pass	28820	Pass
28821	Pass	28822	Pass	28823	Pass	28824	Pass
28825	Pass	28826	Pass	28827	Pass	28828	Pass
28829	Pass	28830	Pass	28831	Pass	28832	Pass
28833	Pass	28834	Pass	28835	Pass	28836	Pass
28837	Pass	28838	Pass	28839	Pass	28840	Pass
28841	Pass	28842	Pass	28843	Pass	28844	Pass
28845	Pass	28846	Pass	28847	Pass	28848	Pass
28849	Pass	28850	Pass	28851	Pass	28852	Pass
28853	Pass	28854	Pass	28855	Pass	28856	Pass
28857	Pass	28858	Pass	28859	Pass	28860	Pass
28861	Pass	28862	Pass	28863	Pass	28864	Pass
28865	Pass	28866	Pass	28867	Pass	28868	Pass
28869	Pass	28870	Pass	28871	Pass	28872	Pass
28873	Pass	28874	Pass	28875	Pass	28876	Pass
28877	Pass	28878	Pass	28879	Pass	28880	Pass
28881	Pass	28882	Pass	28883	Pass	28884	Pass
28885	Pass	28886	Pass	28887	Pass	28888	Pass
28889	Pass	28890	Pass	28891	Pass	28892	Pass
28893	Pass	28894	Pass	28895	Pass	28896	Pass
28897	Pass	28898	Pass	28899	Pass	28900	Pass

Remarks: This is to certify that the above mentioned Fire Extinguishers are tested for hydraulic pressure of 35 bar for 2.5 minute and found satisfactory. No any leakage observed.



Authorized Signatory