

HYDRO PRESSURE TEST

TC No.: HPT/MOD5/CA/RQ/078/25	Model No.: KMCRQ-5	Date: 18-12-2025
Type and Capacity of Extinguisher	: KMCRQ-5-Kanex Clean Agent Modular HFC Based Fire Extinguisher Cap. 5 Kg.	
Batch Number	: KMCRQ5 078/25	
Batch Quantity	: 50.00 Nos.	
Serial Numbers	: 03851 To 3900	
Month of Manufacturing	: Dec/25	

Sr. Nos.	Result	Sr. Nos.	Result	Sr. Nos.	Result	Sr. Nos.	Result
Burst test conducted on 03851 To 3900 and removed from the Lot/Batch							
3851	Pass	3852	Pass	3853	Pass	3854	Pass
3855	Pass	3856	Pass	3857	Pass	3858	Pass
3859	Pass	3860	Pass	3861	Pass	3862	Pass
3863	Pass	3864	Pass	3865	Pass	3866	Pass
3867	Pass	3868	Pass	3869	Pass	3870	Pass
3871	Pass	3872	Pass	3873	Pass	3874	Pass
3875	Pass	3876	Pass	3877	Pass	3878	Pass
3879	Pass	3880	Pass	3881	Pass	3882	Pass
3883	Pass	3884	Pass	3885	Pass	3886	Pass
3887	Pass	3888	Pass	3889	Pass	3890	Pass
3891	Pass	3892	Pass	3893	Pass	3894	Pass
3895	Pass	3896	Pass	3897	Pass	3898	Pass
3899	Pass	3900	Pass				

Remarks: This is to certify that the above mentioned Fire Extinguishers are tested for hydraulic pressure of 35 bar for 2.5 minute and found satisfactory. No any leakage observed.



Authorized Signatory