

HYDRO PRESSURE TEST

TC No.: HPT/MOD5/CA/RQ/076/25	Model No.: KMCRQ-5	Date: 12-12-2025
Type and Capacity of Extinguisher	: KMCRQ-5-Kanex Clean Agent Modular HFC Based Fire Extinguisher Cap. 5 Kg.	
Batch Number	: KMCRQ5 076/25	
Batch Quantity	: 50.00 Nos.	
Serial Numbers	: 03751 To 3800	
Month of Manufacturing	: Dec/25	

Sr. Nos.	Result	Sr. Nos.	Result	Sr. Nos.	Result	Sr. Nos.	Result
Burst test conducted on 03751 To 3800 and removed from the Lot/Batch							
3751	Pass	3752	Pass	3753	Pass	3754	Pass
3755	Pass	3756	Pass	3757	Pass	3758	Pass
3759	Pass	3760	Pass	3761	Pass	3762	Pass
3763	Pass	3764	Pass	3765	Pass	3766	Pass
3767	Pass	3768	Pass	3769	Pass	3770	Pass
3771	Pass	3772	Pass	3773	Pass	3774	Pass
3775	Pass	3776	Pass	3777	Pass	3778	Pass
3779	Pass	3780	Pass	3781	Pass	3782	Pass
3783	Pass	3784	Pass	3785	Pass	3786	Pass
3787	Pass	3788	Pass	3789	Pass	3790	Pass
3791	Pass	3792	Pass	3793	Pass	3794	Pass
3795	Pass	3796	Pass	3797	Pass	3798	Pass
3799	Pass	3800	Pass				

Remarks: This is to certify that the above mentioned Fire Extinguishers are tested for hydraulic pressure of 35 bar for 2.5 minute and found satisfactory. No any leakage observed.



Authorized Signatory