

HYDRO PRESSURE TEST

TC No.: HPT/A2/A90/RQ/103/25	Model No.: KFARQ-2-90%	Date: 23-12-2025
Type and Capacity of Extinguisher	: KFARQ-2-90%-Kanex ABC Dry Powder Fire Extinguisher Cap. 2 Kg.	
Batch Number	: KFARQ90%2 103/25	
Batch Quantity	: 101.00 Nos.	
Serial Numbers	: 10201 To 10300 And 10205A	
Month of Manufacturing	: Dec/25	

Sr. Nos.	Result	Sr. Nos.	Result	Sr. Nos.	Result	Sr. Nos.	Result
Burst test conducted on 10205A and removed from the Lot/Batch							
10201	Pass	10202	Pass	10203	Pass	10204	Pass
10205	Pass	10206	Pass	10207	Pass	10208	Pass
10209	Pass	10210	Pass	10211	Pass	10212	Pass
10213	Pass	10214	Pass	10215	Pass	10216	Pass
10217	Pass	10218	Pass	10219	Pass	10220	Pass
10221	Pass	10222	Pass	10223	Pass	10224	Pass
10225	Pass	10226	Pass	10227	Pass	10228	Pass
10229	Pass	10230	Pass	10231	Pass	10232	Pass
10233	Pass	10234	Pass	10235	Pass	10236	Pass
10237	Pass	10238	Pass	10239	Pass	10240	Pass
10241	Pass	10242	Pass	10243	Pass	10244	Pass
10245	Pass	10246	Pass	10247	Pass	10248	Pass
10249	Pass	10250	Pass	10251	Pass	10252	Pass
10253	Pass	10254	Pass	10255	Pass	10256	Pass
10257	Pass	10258	Pass	10259	Pass	10260	Pass
10261	Pass	10262	Pass	10263	Pass	10264	Pass
10265	Pass	10266	Pass	10267	Pass	10268	Pass
10269	Pass	10270	Pass	10271	Pass	10272	Pass
10273	Pass	10274	Pass	10275	Pass	10276	Pass
10277	Pass	10278	Pass	10279	Pass	10280	Pass
10281	Pass	10282	Pass	10283	Pass	10284	Pass
10285	Pass	10286	Pass	10287	Pass	10288	Pass
10289	Pass	10290	Pass	10291	Pass	10292	Pass
10293	Pass	10294	Pass	10295	Pass	10296	Pass
10297	Pass	10298	Pass	10299	Pass	10300	Pass

Remarks: This is to certify that the above mentioned Fire Extinguishers are tested for hydraulic pressure of 35 bar for 2.5 minute and found satisfactory. No any leakage observed.



Authorized Signatory