

HYDRO PRESSURE TEST

TC No.: HPT/MOD10/CA/RQ/196/25	Model No.: KMCRQ-10	Date: 20-12-2025
Type and Capacity of Extinguisher	: KMCRQ-10-Kanex Clean Agent Modular HFC Based Fire Extinguisher Cap. 10 Kg.	
Batch Number	: KMCRQ10 196/25	
Batch Quantity	: 10.00 Nos.	
Serial Numbers	: 01951 To 1960	
Month of Manufacturing	: Dec/25	

Sr. Nos.	Result	Sr. Nos.	Result	Sr. Nos.	Result	Sr. Nos.	Result
Burst test conducted on 01951 To 1960 and removed from the Lot/Batch							
1951	Pass	1952	Pass	1953	Pass	1954	Pass
1955	Pass	1956	Pass	1957	Pass	1958	Pass
1959	Pass	1960	Pass				

Remarks: This is to certify that the above mentioned Fire Extinguishers are tested for hydraulic pressure of 35 bar for 2.5 minute and found satisfactory. No any leakage observed.



Authorized Signatory