

HYDRO PRESSURE TEST

TC No.: HPT/F45/RQ/054/25	Model No.: KFMRQ-45	Date: 12-12-2025
Type and Capacity of Extinguisher	: KFMRQ-45-Kanex M Foam Trolley Mounted Fire Extinguisher Cap. 45 Ltr.	
Batch Number	: KFMRQ45 054/25	
Batch Quantity	: 50.00 Nos.	
Serial Numbers	: 02651 To 2700	
Month of Manufacturing	: Dec/25	

Sr. Nos.	Result	Sr. Nos.	Result	Sr. Nos.	Result	Sr. Nos.	Result
Burst test conducted on Cylinder Sr.No.2505A and which is removed from the batch (51st batch)							
2651	Pass	2652	Pass	2653	Pass	2654	Pass
2655	Pass	2656	Pass	2657	Pass	2658	Pass
2659	Pass	2660	Pass	2661	Pass	2662	Pass
2663	Pass	2664	Pass	2665	Pass	2666	Pass
2667	Pass	2668	Pass	2669	Pass	2670	Pass
2671	Pass	2672	Pass	2673	Pass	2674	Pass
2675	Pass	2676	Pass	2677	Pass	2678	Pass
2679	Pass	2680	Pass	2681	Pass	2682	Pass
2683	Pass	2684	Pass	2685	Pass	2686	Pass
2687	Pass	2688	Pass	2689	Pass	2690	Pass
2691	Pass	2692	Pass	2693	Pass	2694	Pass
2695	Pass	2696	Pass	2697	Pass	2698	Pass
2699	Pass	2700	Pass				

Remarks: This is to certify that the above mentioned Fire Extinguishers are tested for hydraulic pressure of 35 bar for 2.5 Minute and found satisfactory. No any leakage observed.



Authorized Signatory