

# HYDRO PRESSURE TEST

|                                   |                                                                    |                  |
|-----------------------------------|--------------------------------------------------------------------|------------------|
| TC No.: HPT/WM4/HQ/001/26         | Model No.: KFWMSHQ-4                                               | Date: 08-01-2026 |
| Type and Capacity of Extinguisher | : KFWMSHQ-4-Water Mist Type Portable Fire Extinguisher Cap. 4 Ltr. |                  |
| Batch Number                      | : KFWMSHQ4 001/26                                                  |                  |
| Batch Quantity                    | : 10.00 Nos.                                                       |                  |
| Serial Numbers                    | : 00001 To 10                                                      |                  |
| Month of Manufacturing            | : Jan/26                                                           |                  |

| Sr. Nos.                                                           | Result | Sr. Nos. | Result | Sr. Nos. | Result | Sr. Nos. | Result |
|--------------------------------------------------------------------|--------|----------|--------|----------|--------|----------|--------|
| Burst test conducted on 00001 To 10 and removed from the Lot/Batch |        |          |        |          |        |          |        |
| 1                                                                  | Pass   | 2        | Pass   | 3        | Pass   | 4        | Pass   |
| 5                                                                  | Pass   | 6        | Pass   | 7        | Pass   | 8        | Pass   |
| 9                                                                  | Pass   | 10       | Pass   |          |        |          |        |

**Remarks:** This is to certify that the above mentioned Fire Extinguishers are tested for hydraulic pressure of 35 bar for 2.5 minute and found satisfactory. No any leakage observed.



**Authorized Signatory**