

HYDRO PRESSURE TEST

TC No.: HPT/A2/A90/RQ/102/25	Model No.: KFARQ-2-90%	Date: 15-12-2025
Type and Capacity of Extinguisher	: KFARQ-2-90%-Kanex ABC Dry Powder Fire Extinguisher Cap. 2 Kg.	
Batch Number	: KFARQ90%2 102/25	
Batch Quantity	: 101.00 Nos.	
Serial Numbers	: 10101 To 10200 And 10105A	
Month of Manufacturing	: Dec/25	

Sr. Nos.	Result	Sr. Nos.	Result	Sr. Nos.	Result	Sr. Nos.	Result
Burst test conducted on 10105A and removed from the Lot/Batch							
10101	Pass	10102	Pass	10103	Pass	10104	Pass
10105	Pass	10106	Pass	10107	Pass	10108	Pass
10109	Pass	10110	Pass	10111	Pass	10112	Pass
10113	Pass	10114	Pass	10115	Pass	10116	Pass
10117	Pass	10118	Pass	10119	Pass	10120	Pass
10121	Pass	10122	Pass	10123	Pass	10124	Pass
10125	Pass	10126	Pass	10127	Pass	10128	Pass
10129	Pass	10130	Pass	10131	Pass	10132	Pass
10133	Pass	10134	Pass	10135	Pass	10136	Pass
10137	Pass	10138	Pass	10139	Pass	10140	Pass
10141	Pass	10142	Pass	10143	Pass	10144	Pass
10145	Pass	10146	Pass	10147	Pass	10148	Pass
10149	Pass	10150	Pass	10151	Pass	10152	Pass
10153	Pass	10154	Pass	10155	Pass	10156	Pass
10157	Pass	10158	Pass	10159	Pass	10160	Pass
10161	Pass	10162	Pass	10163	Pass	10164	Pass
10165	Pass	10166	Pass	10167	Pass	10168	Pass
10169	Pass	10170	Pass	10171	Pass	10172	Pass
10173	Pass	10174	Pass	10175	Pass	10176	Pass
10177	Pass	10178	Pass	10179	Pass	10180	Pass
10181	Pass	10182	Pass	10183	Pass	10184	Pass
10185	Pass	10186	Pass	10187	Pass	10188	Pass
10189	Pass	10190	Pass	10191	Pass	10192	Pass
10193	Pass	10194	Pass	10195	Pass	10196	Pass
10197	Pass	10198	Pass	10199	Pass	10200	Pass

Remarks: This is to certify that the above mentioned Fire Extinguishers are tested for hydraulic pressure of 35 bar for 2.5 minute and found satisfactory. No any leakage observed.



Authorized Signatory