

HYDRO PRESSURE TEST

TC No.: HPT/A4/A90/RQ/191/25	Model No.: KFARQ-4-90%	Date: 16-11-2025
Type and Capacity of Extinguisher	: KFARQ-4-90%-Kanex ABC Dry Powder Fire Extinguisher Cap. 4 Kg.	
Batch Number	: KFARQ90%4 191/25	
Batch Quantity	: 101.00 Nos.	
Serial Numbers	: 19001 To 19100 And 19005A	
Month of Manufacturing	: Nov/25	

Sr. Nos.	Result	Sr. Nos.	Result	Sr. Nos.	Result	Sr. Nos.	Result
Burst test conducted on 19005A and removed from the Lot/Batch							
19001	Pass	19002	Pass	19003	Pass	19004	Pass
19005	Pass	19006	Pass	19007	Pass	19008	Pass
19009	Pass	19010	Pass	19011	Pass	19012	Pass
19013	Pass	19014	Pass	19015	Pass	19016	Pass
19017	Pass	19018	Pass	19019	Pass	19020	Pass
19021	Pass	19022	Pass	19023	Pass	19024	Pass
19025	Pass	19026	Pass	19027	Pass	19028	Pass
19029	Pass	19030	Pass	19031	Pass	19032	Pass
19033	Pass	19034	Pass	19035	Pass	19036	Pass
19037	Pass	19038	Pass	19039	Pass	19040	Pass
19041	Pass	19042	Pass	19043	Pass	19044	Pass
19045	Pass	19046	Pass	19047	Pass	19048	Pass
19049	Pass	19050	Pass	19051	Pass	19052	Pass
19053	Pass	19054	Pass	19055	Pass	19056	Pass
19057	Pass	19058	Pass	19059	Pass	19060	Pass
19061	Pass	19062	Pass	19063	Pass	19064	Pass
19065	Pass	19066	Pass	19067	Pass	19068	Pass
19069	Pass	19070	Pass	19071	Pass	19072	Pass
19073	Pass	19074	Pass	19075	Pass	19076	Pass
19077	Pass	19078	Pass	19079	Pass	19080	Pass
19081	Pass	19082	Pass	19083	Pass	19084	Pass
19085	Pass	19086	Pass	19087	Pass	19088	Pass
19089	Pass	19090	Pass	19091	Pass	19092	Pass
19093	Pass	19094	Pass	19095	Pass	19096	Pass
19097	Pass	19098	Pass	19099	Pass	19100	Pass

Remarks: This is to certify that the above mentioned Fire Extinguishers are tested for hydraulic pressure of 35 bar for 2.5 minute and found satisfactory. No any leakage observed.



Authorized Signatory