

HYDRO PRESSURE TEST

TC No.: HPT/A6/A50/RQ/350/25	Model No.: KFARQ-6-50%	Date: 18-12-2025
Type and Capacity of Extinguisher	: KFARQ-6-50%-Kanex ABC Dry Powder Fire Extinguisher Cap. 6 Kg.	
Batch Number	: KFARQ50%6 350/25	
Batch Quantity	: 101.00 Nos.	
Serial Numbers	: 34901 To 35000 And 34905A	
Month of Manufacturing	: Dec/25	

Sr. Nos.	Result	Sr. Nos.	Result	Sr. Nos.	Result	Sr. Nos.	Result
Burst test conducted on 34905A and removed from the Lot/Batch							
34901	Pass	34902	Pass	34903	Pass	34904	Pass
34905	Pass	34906	Pass	34907	Pass	34908	Pass
34909	Pass	34910	Pass	34911	Pass	34912	Pass
34913	Pass	34914	Pass	34915	Pass	34916	Pass
34917	Pass	34918	Pass	34919	Pass	34920	Pass
34921	Pass	34922	Pass	34923	Pass	34924	Pass
34925	Pass	34926	Pass	34927	Pass	34928	Pass
34929	Pass	34930	Pass	34931	Pass	34932	Pass
34933	Pass	34934	Pass	34935	Pass	34936	Pass
34937	Pass	34938	Pass	34939	Pass	34940	Pass
34941	Pass	34942	Pass	34943	Pass	34944	Pass
34945	Pass	34946	Pass	34947	Pass	34948	Pass
34949	Pass	34950	Pass	34951	Pass	34952	Pass
34953	Pass	34954	Pass	34955	Pass	34956	Pass
34957	Pass	34958	Pass	34959	Pass	34960	Pass
34961	Pass	34962	Pass	34963	Pass	34964	Pass
34965	Pass	34966	Pass	34967	Pass	34968	Pass
34969	Pass	34970	Pass	34971	Pass	34972	Pass
34973	Pass	34974	Pass	34975	Pass	34976	Pass
34977	Pass	34978	Pass	34979	Pass	34980	Pass
34981	Pass	34982	Pass	34983	Pass	34984	Pass
34985	Pass	34986	Pass	34987	Pass	34988	Pass
34989	Pass	34990	Pass	34991	Pass	34992	Pass
34993	Pass	34994	Pass	34995	Pass	34996	Pass
34997	Pass	34998	Pass	34999	Pass	35000	Pass

Remarks: This is to certify that the above mentioned Fire Extinguishers are tested for hydraulic pressure of 35 bar for 2.5 minute and found satisfactory. No any leakage observed.



SIHOR
(GUJARAT)

Authorized Signatory