

HYDRO PRESSURE TEST

TC No.: HPT/A6/A50/RQ/351/25	Model No.: KFARQ-6-50%	Date: 18-12-2025
Type and Capacity of Extinguisher	: KFARQ-6-50%-Kanex ABC Dry Powder Fire Extinguisher Cap. 6 Kg.	
Batch Number	: KFARQ50%6 351/25	
Batch Quantity	: 101.00 Nos.	
Serial Numbers	: 35001 To 35100 And 35005A	
Month of Manufacturing	: Dec/25	

Sr. Nos.	Result	Sr. Nos.	Result	Sr. Nos.	Result	Sr. Nos.	Result
Burst test conducted on 35005A and removed from the Lot/Batch							
35001	Pass	35002	Pass	35003	Pass	35004	Pass
35005	Pass	35006	Pass	35007	Pass	35008	Pass
35009	Pass	35010	Pass	35011	Pass	35012	Pass
35013	Pass	35014	Pass	35015	Pass	35016	Pass
35017	Pass	35018	Pass	35019	Pass	35020	Pass
35021	Pass	35022	Pass	35023	Pass	35024	Pass
35025	Pass	35026	Pass	35027	Pass	35028	Pass
35029	Pass	35030	Pass	35031	Pass	35032	Pass
35033	Pass	35034	Pass	35035	Pass	35036	Pass
35037	Pass	35038	Pass	35039	Pass	35040	Pass
35041	Pass	35042	Pass	35043	Pass	35044	Pass
35045	Pass	35046	Pass	35047	Pass	35048	Pass
35049	Pass	35050	Pass	35051	Pass	35052	Pass
35053	Pass	35054	Pass	35055	Pass	35056	Pass
35057	Pass	35058	Pass	35059	Pass	35060	Pass
35061	Pass	35062	Pass	35063	Pass	35064	Pass
35065	Pass	35066	Pass	35067	Pass	35068	Pass
35069	Pass	35070	Pass	35071	Pass	35072	Pass
35073	Pass	35074	Pass	35075	Pass	35076	Pass
35077	Pass	35078	Pass	35079	Pass	35080	Pass
35081	Pass	35082	Pass	35083	Pass	35084	Pass
35085	Pass	35086	Pass	35087	Pass	35088	Pass
35089	Pass	35090	Pass	35091	Pass	35092	Pass
35093	Pass	35094	Pass	35095	Pass	35096	Pass
35097	Pass	35098	Pass	35099	Pass	35100	Pass

Remarks: This is to certify that the above mentioned Fire Extinguishers are tested for hydraulic pressure of 35 bar for 2.5 minute and found satisfactory. No any leakage observed.



Authorized Signatory