

HYDRO PRESSURE TEST

TC No.: HPT/A6/A50/RQ/352/25	Model No.: KFARQ-6-50%	Date: 18-12-2025
Type and Capacity of Extinguisher	: KFARQ-6-50%-Kanex ABC Dry Powder Fire Extinguisher Cap. 6 Kg.	
Batch Number	: KFARQ50%6 352/25	
Batch Quantity	: 101.00 Nos.	
Serial Numbers	: 35101 To 35200 And 35105A	
Month of Manufacturing	: Dec/25	

Sr. Nos.	Result	Sr. Nos.	Result	Sr. Nos.	Result	Sr. Nos.	Result
Burst test conducted on 35105A and removed from the Lot/Batch							
35101	Pass	35102	Pass	35103	Pass	35104	Pass
35105	Pass	35106	Pass	35107	Pass	35108	Pass
35109	Pass	35110	Pass	35111	Pass	35112	Pass
35113	Pass	35114	Pass	35115	Pass	35116	Pass
35117	Pass	35118	Pass	35119	Pass	35120	Pass
35121	Pass	35122	Pass	35123	Pass	35124	Pass
35125	Pass	35126	Pass	35127	Pass	35128	Pass
35129	Pass	35130	Pass	35131	Pass	35132	Pass
35133	Pass	35134	Pass	35135	Pass	35136	Pass
35137	Pass	35138	Pass	35139	Pass	35140	Pass
35141	Pass	35142	Pass	35143	Pass	35144	Pass
35145	Pass	35146	Pass	35147	Pass	35148	Pass
35149	Pass	35150	Pass	35151	Pass	35152	Pass
35153	Pass	35154	Pass	35155	Pass	35156	Pass
35157	Pass	35158	Pass	35159	Pass	35160	Pass
35161	Pass	35162	Pass	35163	Pass	35164	Pass
35165	Pass	35166	Pass	35167	Pass	35168	Pass
35169	Pass	35170	Pass	35171	Pass	35172	Pass
35173	Pass	35174	Pass	35175	Pass	35176	Pass
35177	Pass	35178	Pass	35179	Pass	35180	Pass
35181	Pass	35182	Pass	35183	Pass	35184	Pass
35185	Pass	35186	Pass	35187	Pass	35188	Pass
35189	Pass	35190	Pass	35191	Pass	35192	Pass
35193	Pass	35194	Pass	35195	Pass	35196	Pass
35197	Pass	35198	Pass	35199	Pass	35200	Pass

Remarks: This is to certify that the above mentioned Fire Extinguishers are tested for hydraulic pressure of 35 bar for 2.5 minute and found satisfactory. No any leakage observed.



Authorized Signatory