

HELIUM LEAK DETECTION TEST

TC No.: HLD/WM4/HQ/001/26	Model No.: KFWMSHQ-4	Date: 10-01-2026
Type and Capacity of Extinguisher	: KFWMSHQ-4-Water Mist Type Portable Fire Extinguisher Cap. 4 Ltr.	
Batch Number	: KFWMSHQ4 001/26	
Batch Quantity	: 10 Nos.	
Serial Numbers	: 00001 To 10	
Month of Manufacturing	: Jan/26	

Sr. Nos.	Result	Sr. Nos.	Result	Sr. Nos.	Result	Sr. Nos.	Result
1	Pass	2	Pass	3	Pass	4	Pass
5	Pass	6	Pass	7	Pass	8	Pass
9	Pass	10	Pass				

Remarks: This is to certify that the above mentioned Fire Extinguishers has been tested on Mass Spectrometer Helium Leak Detector, with test pressure of 1 mbar and desired leak rate of 1×10^{-6} mbar.l/sec and no any cylinders shows leakage beyond this limit.



Authorized Signatory