

HYDRO PRESSURE TEST

TC No.: HPT/F9/SP/RQ/069/25	Model No.: KFMSRQ-9	Date: 02-11-2025
Type and Capacity of Extinguisher	: KFMSRQ-9-Kanex M Foam SP Fire Extinguisher Cap. 9 Ltr.	
Batch Number	: KFMSRQ9 069/25	
Batch Quantity	: 101.00 Nos.	
Serial Numbers	: 06801 To 6900 And 6805A	
Month of Manufacturing	: Nov/25	

Sr. Nos.	Result	Sr. Nos.	Result	Sr. Nos.	Result	Sr. Nos.	Result
Burst test conducted on 6805A and removed from the Lot/Batch							
6801	Pass	6802	Pass	6803	Pass	6804	Pass
6805	Pass	6806	Pass	6807	Pass	6808	Pass
6809	Pass	6810	Pass	6811	Pass	6812	Pass
6813	Pass	6814	Pass	6815	Pass	6816	Pass
6817	Pass	6818	Pass	6819	Pass	6820	Pass
6821	Pass	6822	Pass	6823	Pass	6824	Pass
6825	Pass	6826	Pass	6827	Pass	6828	Pass
6829	Pass	6830	Pass	6831	Pass	6832	Pass
6833	Pass	6834	Pass	6835	Pass	6836	Pass
6837	Pass	6838	Pass	6839	Pass	6840	Pass
6841	Pass	6842	Pass	6843	Pass	6844	Pass
6845	Pass	6846	Pass	6847	Pass	6848	Pass
6849	Pass	6850	Pass	6851	Pass	6852	Pass
6853	Pass	6854	Pass	6855	Pass	6856	Pass
6857	Pass	6858	Pass	6859	Pass	6860	Pass
6861	Pass	6862	Pass	6863	Pass	6864	Pass
6865	Pass	6866	Pass	6867	Pass	6868	Pass
6869	Pass	6870	Pass	6871	Pass	6872	Pass
6873	Pass	6874	Pass	6875	Pass	6876	Pass
6877	Pass	6878	Pass	6879	Pass	6880	Pass
6881	Pass	6882	Pass	6883	Pass	6884	Pass
6885	Pass	6886	Pass	6887	Pass	6888	Pass
6889	Pass	6890	Pass	6891	Pass	6892	Pass
6893	Pass	6894	Pass	6895	Pass	6896	Pass
6897	Pass	6898	Pass	6899	Pass	6900	Pass

Remarks: This is to certify that the above mentioned Fire Extinguishers are tested for hydraulic pressure of 35 bar for 2.5 minute and found satisfactory. No any leakage observed.



Authorized Signatory