

HELIUM LEAK DETECTION TEST

TC No.: HLD/A3/K/HQ/002/26

Model No.: KFKHQ-3

Date: 29-01-2026

Type and Capacity of Extinguisher : KFKHQ-3-Kanex F Class Kitchen Fire Extinguisher Cap. 3 Ltr.

Batch Number : KFKHQ3 002/26

Batch Quantity : 10 Nos.

Serial Numbers : 00011 To 20

Month of Manufacturing : Jan/26

Sr. Nos.	Result	Sr. Nos.	Result	Sr. Nos.	Result	Sr. Nos.	Result
11	Pass	12	Pass	13	Pass	14	Pass
15	Pass	16	Pass	17	Pass	18	Pass
19	Pass	20	Pass				

Remarks: This is to certify that the above mentioned Fire Extinguishers has been tested on Mass Spectrometer Helium Leak Detector, with test pressure of 1 mbar and desired leak rate of 1×10^{-6} mbar.l/sec and no any cylinders shows leakage beyond this limit.

**Authorized Signatory**