

HYDRO PRESSURE TEST

TC No.: HPT/MOD10/CA/RQ/192/25	Model No.: KMCRQ-10	Date: 15-12-2025
Type and Capacity of Extinguisher	: KMCRQ-10-Kanex Clean Agent Modular HFC Based Fire Extinguisher Cap. 10 Kg.	
Batch Number	: KMCRQ10 192/25	
Batch Quantity	: 10.00 Nos.	
Serial Numbers	: 01911 To 1920	
Month of Manufacturing	: Dec/25	

Sr. Nos.	Result	Sr. Nos.	Result	Sr. Nos.	Result	Sr. Nos.	Result
Burst test conducted on 01911 To 1920 and removed from the Lot/Batch							
1911	Pass	1912	Pass	1913	Pass	1914	Pass
1915	Pass	1916	Pass	1917	Pass	1918	Pass
1919	Pass	1920	Pass				

Remarks: This is to certify that the above mentioned Fire Extinguishers are tested for hydraulic pressure of 35 bar for 2.5 minute and found satisfactory. No any leakage observed.



Authorized Signatory