

HYDRO PRESSURE TEST

TC No.: HPT/MOD10/CA/RQ/194/25	Model No.: KMCRQ-10	Date: 18-12-2025
Type and Capacity of Extinguisher	: KMCRQ-10-Kanex Clean Agent Modular HFC Based Fire Extinguisher Cap. 10 Kg.	
Batch Number	: KMCRQ10 194/25	
Batch Quantity	: 10.00 Nos.	
Serial Numbers	: 01931 To 1940	
Month of Manufacturing	: Dec/25	

Sr. Nos.	Result	Sr. Nos.	Result	Sr. Nos.	Result	Sr. Nos.	Result
Burst test conducted on 01931 To 1940 and removed from the Lot/Batch							
1931	Pass	1932	Pass	1933	Pass	1934	Pass
1935	Pass	1936	Pass	1937	Pass	1938	Pass
1939	Pass	1940	Pass				

Remarks: This is to certify that the above mentioned Fire Extinguishers are tested for hydraulic pressure of 35 bar for 2.5 minute and found satisfactory. No any leakage observed.



Authorized Signatory