

HYDRO PRESSURE TEST

TC No.: HPT/MA6/A40/RQ/299/25	Model No.: MARQ-6-50%	Date: 26-09-2025
Type and Capacity of Extinguisher	: MARQ-6-50%-Kanex ABC Dry Powder Fire Extinguisher Cap. 6 Kg.	
Batch Number	: MARQ50%6 299/25	
Batch Quantity	: 101.00 Nos.	
Serial Numbers	: 29801 To 29900 And 29805A	
Month of Manufacturing	: Sep/25	

Sr. Nos.	Result	Sr. Nos.	Result	Sr. Nos.	Result	Sr. Nos.	Result
Burst test conducted on 29805A and removed from the Lot/Batch							
29801	Pass	29802	Pass	29803	Pass	29804	Pass
29805	Pass	29806	Pass	29807	Pass	29808	Pass
29809	Pass	29810	Pass	29811	Pass	29812	Pass
29813	Pass	29814	Pass	29815	Pass	29816	Pass
29817	Pass	29818	Pass	29819	Pass	29820	Pass
29821	Pass	29822	Pass	29823	Pass	29824	Pass
29825	Pass	29826	Pass	29827	Pass	29828	Pass
29829	Pass	29830	Pass	29831	Pass	29832	Pass
29833	Pass	29834	Pass	29835	Pass	29836	Pass
29837	Pass	29838	Pass	29839	Pass	29840	Pass
29841	Pass	29842	Pass	29843	Pass	29844	Pass
29845	Pass	29846	Pass	29847	Pass	29848	Pass
29849	Pass	29850	Pass	29851	Pass	29852	Pass
29853	Pass	29854	Pass	29855	Pass	29856	Pass
29857	Pass	29858	Pass	29859	Pass	29860	Pass
29861	Pass	29862	Pass	29863	Pass	29864	Pass
29865	Pass	29866	Pass	29867	Pass	29868	Pass
29869	Pass	29870	Pass	29871	Pass	29872	Pass
29873	Pass	29874	Pass	29875	Pass	29876	Pass
29877	Pass	29878	Pass	29879	Pass	29880	Pass
29881	Pass	29882	Pass	29883	Pass	29884	Pass
29885	Pass	29886	Pass	29887	Pass	29888	Pass
29889	Pass	29890	Pass	29891	Pass	29892	Pass
29893	Pass	29894	Pass	29895	Pass	29896	Pass
29897	Pass	29898	Pass	29899	Pass	29900	Pass

Remarks: This is to certify that the above mentioned Fire Extinguishers are tested for hydraulic pressure of 35 bar for 2.5 minute and found satisfactory. No any leakage observed.



Authorized Signatory