

HYDRO PRESSURE TEST

TC No.: HPT/MA6/A40/RQ/300/25	Model No.: MARQ-6-50%	Date: 26-09-2025
Type and Capacity of Extinguisher	: MARQ-6-50%-Kanex ABC Dry Powder Fire Extinguisher Cap. 6 Kg.	
Batch Number	: MARQ50%6 300/25	
Batch Quantity	: 101.00 Nos.	
Serial Numbers	: 29901 To 30000 And 29905A	
Month of Manufacturing	: Sep/25	

Sr. Nos.	Result	Sr. Nos.	Result	Sr. Nos.	Result	Sr. Nos.	Result
Burst test conducted on 29905A and removed from the Lot/Batch							
29901	Pass	29902	Pass	29903	Pass	29904	Pass
29905	Pass	29906	Pass	29907	Pass	29908	Pass
29909	Pass	29910	Pass	29911	Pass	29912	Pass
29913	Pass	29914	Pass	29915	Pass	29916	Pass
29917	Pass	29918	Pass	29919	Pass	29920	Pass
29921	Pass	29922	Pass	29923	Pass	29924	Pass
29925	Pass	29926	Pass	29927	Pass	29928	Pass
29929	Pass	29930	Pass	29931	Pass	29932	Pass
29933	Pass	29934	Pass	29935	Pass	29936	Pass
29937	Pass	29938	Pass	29939	Pass	29940	Pass
29941	Pass	29942	Pass	29943	Pass	29944	Pass
29945	Pass	29946	Pass	29947	Pass	29948	Pass
29949	Pass	29950	Pass	29951	Pass	29952	Pass
29953	Pass	29954	Pass	29955	Pass	29956	Pass
29957	Pass	29958	Pass	29959	Pass	29960	Pass
29961	Pass	29962	Pass	29963	Pass	29964	Pass
29965	Pass	29966	Pass	29967	Pass	29968	Pass
29969	Pass	29970	Pass	29971	Pass	29972	Pass
29973	Pass	29974	Pass	29975	Pass	29976	Pass
29977	Pass	29978	Pass	29979	Pass	29980	Pass
29981	Pass	29982	Pass	29983	Pass	29984	Pass
29985	Pass	29986	Pass	29987	Pass	29988	Pass
29989	Pass	29990	Pass	29991	Pass	29992	Pass
29993	Pass	29994	Pass	29995	Pass	29996	Pass
29997	Pass	29998	Pass	29999	Pass	30000	Pass

Remarks: This is to certify that the above mentioned Fire Extinguishers are tested for hydraulic pressure of 35 bar for 2.5 minute and found satisfactory. No any leakage observed.



Authorized Signatory