



Warranty Certificate

Date: 04-11-2025**Manufacturer:** Kanex Fire Solutions Limited.**Customer Name:** Indu Fire Services**Warranty Start Date:** 04-11-2025**Warranty End Date:** 03-11-2026.

This is to certify that the below extinguishers are warranted for a period of **1** year from the date of supply against any of Manufacturing/Quality defects.

NOTE – IF TAMPER SEAL IS NOT INTACT, THE WARRANTY SHALL BE CONSIDERED VOID.

Sr.No.	Type & Capacity of Extinguishers	Quantity	Sr. Nos.
1	MARQ-2-40% Map-40% SP KANEX Fire Extinguisher Cap. 2 Kg.	4	As Per Annexure – I
2	MARQ-4-40%-Kanex ABC Dry Powder Fire Extinguisher Cap. 4 Kg.	6	As Per Annexure – I
3	KMCRQ-5 Clean Agent (HFC 236fa) Modular Type KANEX Fire Extinguisher Cap. 5 Kg.	2	As Per Annexure – I

Also certify that, all the Fire extinguishers supplied against Invoice **No. 25-26/H/000139 Dated: 04-11-2025 P.O.No. IFS/PO/2025-26/052** are hydraulically tested 100% at 35 bar except CO2 and randomly tested for performance test. All the extinguishers confirms to IS 15683:2018 (Portable) or IS 16018:2012 (Mobile) requirements.

Note : If applicable CO2 Cylinders are PESO approved & HPT tested at 225 bar by Cylinder Manufacturer.

**Authorized Signatory**

