

HYDRO PRESSURE TEST

TC No.: HPT/MOD5/CA/RQ/031/25	Model No.: KMCRQ-5	Date: 06-05-2025
Type and Capacity of Extinguisher	: KMCRQ-5-Kanex Clean Agent Modular HFC Based Fire Extinguisher Cap. 5 Kg.	
Batch Number	: KMCRQ5 031/25	
Batch Quantity	: 50.00 Nos.	
Serial Numbers	: 01501 To 1550	
Month of Manufacturing	: May/25	

Sr. Nos.	Result	Sr. Nos.	Result	Sr. Nos.	Result	Sr. Nos.	Result
Burst test conducted on 01501 To 1550 and removed from the Lot/Batch							
1501	Pass	1502	Pass	1503	Pass	1504	Pass
1505	Pass	1506	Pass	1507	Pass	1508	Pass
1509	Pass	1510	Pass	1511	Pass	1512	Pass
1513	Pass	1514	Pass	1515	Pass	1516	Pass
1517	Pass	1518	Pass	1519	Pass	1520	Pass
1521	Pass	1522	Pass	1523	Pass	1524	Pass
1525	Pass	1526	Pass	1527	Pass	1528	Pass
1529	Pass	1530	Pass	1531	Pass	1532	Pass
1533	Pass	1534	Pass	1535	Pass	1536	Pass
1537	Pass	1538	Pass	1539	Pass	1540	Pass
1541	Pass	1542	Pass	1543	Pass	1544	Pass
1545	Pass	1546	Pass	1547	Pass	1548	Pass
1549	Pass	1550	Pass				

Remarks: This is to certify that the above mentioned Fire Extinguishers are tested for hydraulic pressure of 35 bar for 2.5 minute and found satisfactory. No any leakage observed.



Authorized Signatory