

HYDRO PRESSURE TEST

TC No.: HPT/MOD10/CA/RQ/126/25	Model No.: KMCRQ-10	Date: 08-09-2025
Type and Capacity of Extinguisher	: KMCRQ-10-Kanex Clean Agent Modular HFC Based Fire Extinguisher Cap. 10 Kg.	
Batch Number	: KMCRQ10 126/25	
Batch Quantity	: 10.00 Nos.	
Serial Numbers	: 01251 To 1260	
Month of Manufacturing	: Sep/25	

Sr. Nos.	Result	Sr. Nos.	Result	Sr. Nos.	Result	Sr. Nos.	Result
Burst test conducted on 01251 To 1260 and removed from the Lot/Batch							
1251	Pass	1252	Pass	1253	Pass	1254	Pass
1255	Pass	1256	Pass	1257	Pass	1258	Pass
1259	Pass	1260	Pass				

Remarks: This is to certify that the above mentioned Fire Extinguishers are tested for hydraulic pressure of 35 bar for 2.5 minute and found satisfactory. No any leakage observed.



Authorized Signatory