

HYDRO PRESSURE TEST

TC No.: HPT/MOD5/CA/RQ/024/25	Model No.: KMCRQ-5	Date: 17-04-2025
Type and Capacity of Extinguisher	: KMCRQ-5-Kanex Clean Agent Modular HFC Based Fire Extinguisher Cap. 5 Kg.	
Batch Number	: KMCRQ5 024/25	
Batch Quantity	: 50.00 Nos.	
Serial Numbers	: 01151 To 1200	
Month of Manufacturing	: Apr/25	

Sr. Nos.	Result	Sr. Nos.	Result	Sr. Nos.	Result	Sr. Nos.	Result
Burst test conducted on 01151 To 1200 and removed from the Lot/Batch							
1151	Pass	1152	Pass	1153	Pass	1154	Pass
1155	Pass	1156	Pass	1157	Pass	1158	Pass
1159	Pass	1160	Pass	1161	Pass	1162	Pass
1163	Pass	1164	Pass	1165	Pass	1166	Pass
1167	Pass	1168	Pass	1169	Pass	1170	Pass
1171	Pass	1172	Pass	1173	Pass	1174	Pass
1175	Pass	1176	Pass	1177	Pass	1178	Pass
1179	Pass	1180	Pass	1181	Pass	1182	Pass
1183	Pass	1184	Pass	1185	Pass	1186	Pass
1187	Pass	1188	Pass	1189	Pass	1190	Pass
1191	Pass	1192	Pass	1193	Pass	1194	Pass
1195	Pass	1196	Pass	1197	Pass	1198	Pass
1199	Pass	1200	Pass				

Remarks: This is to certify that the above mentioned Fire Extinguishers are tested for hydraulic pressure of 35 bar for 2.5 minute and found satisfactory. No any leakage observed.



Authorized Signatory