



Warranty Certificate

Date: 16-12-2025

Manufacturer: Kanex Fire Solutions Limited.

Customer Name: VR Fire Safety ProductsWarranty Start Date: 16-12-2025Warranty End Date: 15-12-2026.

This is to certify that the below extinguishers are warranted for a period of **1** year from the date of supply against any of Manufacturing/Quality defects.

NOTE – IF TAMPER SEAL IS NOT INTACT, THE WARRANTY SHALL BE CONSIDERED VOID.

Sr.No.	Type & Capacity of Extinguishers	Quantity	Sr. Nos.
1	KCARQ-2-Kanex Clean Agent HFC Based Fire Extinguisher Cap. 2 Kg.	3	As Per Annexure – I
2	KFCRQ-4.5-Kanex CO2 High Pressure Fire Extinguisher Cap. 4.5 Kg.	10	As Per Annexure – I
3	KFDRQ-25-50%-Kanex ABC Dry Powder Fire Extinguisher Cap. 25 Kg.	3	As Per Annexure – I
4	KMCRQ-5-Kanex Clean Agent Modular HFC Based Fire Extinguisher Cap. 5 Kg.	2	As Per Annexure – I
5	KMPRQ-5-50%-Kanex Modular ABC Dry Powder Fire Extinguisher Cap. 5 Kg.	4	As Per Annexure – I
6	MARQ-2-40%-Kanex ABC Dry Powder Fire Extinguisher Cap. 2 Kg.	10	As Per Annexure – I
7	MARQ-2-90%-Kanex ABC Dry Powder Fire Extinguisher Cap. 2 Kg.	6	As Per Annexure – I
8	MARQ-4-40%-Kanex ABC Dry Powder Fire Extinguisher Cap. 4 Kg.	10	As Per Annexure – I

Also certify that, all the Fire extinguishers supplied against Invoice No. **25-26/H/000162 Dated: 16-12-2025 P.O.No. VRFSP/DEC/25-26/050/HYD-37/PO** are hydraulically tested 100% at 35 bar except CO2 and randomly tested for performance test. All the extinguishers confirms to IS 15683:2018 (Portable) or IS 16018:2012 (Mobile) requirements.

Note : If applicable CO2 Cylinders are PESO approved & HPT tested at 225 bar by Cylinder Manufacturer.



Authorized Signatory