

HYDRO PRESSURE TEST

TC No.: HPT/D25/A50/RQ/016/25	Model No.: KFDRQ-25-50%	Date: 23-11-2025
Type and Capacity of Extinguisher	: KFDRQ-25-50%-Kanex ABC Dry Powder Fire Extinguisher Cap. 25 Kg.	
Batch Number	: KFDRQ50%25 016/25	
Batch Quantity	: 50.00 Nos.	
Serial Numbers	: 00751 To 800	
Month of Manufacturing	: Nov/25	

Sr. Nos.	Result	Sr. Nos.	Result	Sr. Nos.	Result	Sr. Nos.	Result
Burst test conducted on Cylinder Sr.No.505A and which is removed from the batch (11th batch)							
751	Pass	752	Pass	753	Pass	754	Pass
755	Pass	756	Pass	757	Pass	758	Pass
759	Pass	760	Pass	761	Pass	762	Pass
763	Pass	764	Pass	765	Pass	766	Pass
767	Pass	768	Pass	769	Pass	770	Pass
771	Pass	772	Pass	773	Pass	774	Pass
775	Pass	776	Pass	777	Pass	778	Pass
779	Pass	780	Pass	781	Pass	782	Pass
783	Pass	784	Pass	785	Pass	786	Pass
787	Pass	788	Pass	789	Pass	790	Pass
791	Pass	792	Pass	793	Pass	794	Pass
795	Pass	796	Pass	797	Pass	798	Pass
799	Pass	800	Pass				

Remarks: This is to certify that the above mentioned Fire Extinguishers are tested for hydraulic pressure of 35 bar for 2.5 Minute and found satisfactory. No any leakage observed.



Authorized Signatory