

# HYDRO PRESSURE TEST

|                                   |                                                                 |                  |
|-----------------------------------|-----------------------------------------------------------------|------------------|
| TC No.: HPT/A6/A50/RQ/311/25      | Model No.: KFARQ-6-50%                                          | Date: 26-09-2025 |
| Type and Capacity of Extinguisher | : KFARQ-6-50%-Kanex ABC Dry Powder Fire Extinguisher Cap. 6 Kg. |                  |
| Batch Number                      | : KFARQ50%6 311/25                                              |                  |
| Batch Quantity                    | : 101.00 Nos.                                                   |                  |
| Serial Numbers                    | : 31001 To 31100 And 31005A                                     |                  |
| Month of Manufacturing            | : Sep/25                                                        |                  |

| Sr. Nos.                                                      | Result | Sr. Nos. | Result | Sr. Nos. | Result | Sr. Nos. | Result |
|---------------------------------------------------------------|--------|----------|--------|----------|--------|----------|--------|
| Burst test conducted on 31005A and removed from the Lot/Batch |        |          |        |          |        |          |        |
| 31001                                                         | Pass   | 31002    | Pass   | 31003    | Pass   | 31004    | Pass   |
| 31005                                                         | Pass   | 31006    | Pass   | 31007    | Pass   | 31008    | Pass   |
| 31009                                                         | Pass   | 31010    | Pass   | 31011    | Pass   | 31012    | Pass   |
| 31013                                                         | Pass   | 31014    | Pass   | 31015    | Pass   | 31016    | Pass   |
| 31017                                                         | Pass   | 31018    | Pass   | 31019    | Pass   | 31020    | Pass   |
| 31021                                                         | Pass   | 31022    | Pass   | 31023    | Pass   | 31024    | Pass   |
| 31025                                                         | Pass   | 31026    | Pass   | 31027    | Pass   | 31028    | Pass   |
| 31029                                                         | Pass   | 31030    | Pass   | 31031    | Pass   | 31032    | Pass   |
| 31033                                                         | Pass   | 31034    | Pass   | 31035    | Pass   | 31036    | Pass   |
| 31037                                                         | Pass   | 31038    | Pass   | 31039    | Pass   | 31040    | Pass   |
| 31041                                                         | Pass   | 31042    | Pass   | 31043    | Pass   | 31044    | Pass   |
| 31045                                                         | Pass   | 31046    | Pass   | 31047    | Pass   | 31048    | Pass   |
| 31049                                                         | Pass   | 31050    | Pass   | 31051    | Pass   | 31052    | Pass   |
| 31053                                                         | Pass   | 31054    | Pass   | 31055    | Pass   | 31056    | Pass   |
| 31057                                                         | Pass   | 31058    | Pass   | 31059    | Pass   | 31060    | Pass   |
| 31061                                                         | Pass   | 31062    | Pass   | 31063    | Pass   | 31064    | Pass   |
| 31065                                                         | Pass   | 31066    | Pass   | 31067    | Pass   | 31068    | Pass   |
| 31069                                                         | Pass   | 31070    | Pass   | 31071    | Pass   | 31072    | Pass   |
| 31073                                                         | Pass   | 31074    | Pass   | 31075    | Pass   | 31076    | Pass   |
| 31077                                                         | Pass   | 31078    | Pass   | 31079    | Pass   | 31080    | Pass   |
| 31081                                                         | Pass   | 31082    | Pass   | 31083    | Pass   | 31084    | Pass   |
| 31085                                                         | Pass   | 31086    | Pass   | 31087    | Pass   | 31088    | Pass   |
| 31089                                                         | Pass   | 31090    | Pass   | 31091    | Pass   | 31092    | Pass   |
| 31093                                                         | Pass   | 31094    | Pass   | 31095    | Pass   | 31096    | Pass   |
| 31097                                                         | Pass   | 31098    | Pass   | 31099    | Pass   | 31100    | Pass   |

**Remarks: This is to certify that the above mentioned Fire Extinguishers are tested for hydraulic pressure of 35 bar for 2.5 minute and found satisfactory. No any leakage observed.**



**Authorized Signatory**