

HYDRO PRESSURE TEST

TC No.: HPT/MOD10/CA/RQ/187/25	Model No.: KMCRQ-10	Date: 12-12-2025
Type and Capacity of Extinguisher	: KMCRQ-10-Kanex Clean Agent Modular HFC Based Fire Extinguisher Cap. 10 Kg.	
Batch Number	: KMCRQ10 187/25	
Batch Quantity	: 10.00 Nos.	
Serial Numbers	: 01861 To 1870	
Month of Manufacturing	: Dec/25	

Sr. Nos.	Result	Sr. Nos.	Result	Sr. Nos.	Result	Sr. Nos.	Result
Burst test conducted on 01861 To 1870 and removed from the Lot/Batch							
1861	Pass	1862	Pass	1863	Pass	1864	Pass
1865	Pass	1866	Pass	1867	Pass	1868	Pass
1869	Pass	1870	Pass				

Remarks: This is to certify that the above mentioned Fire Extinguishers are tested for hydraulic pressure of 35 bar for 2.5 minute and found satisfactory. No any leakage observed.



Authorized Signatory