

# HYDRO PRESSURE TEST

|                                   |                                                                |                  |
|-----------------------------------|----------------------------------------------------------------|------------------|
| TC No.: HPT/MA6/A40/RQ/209/25     | Model No.: MARQ-6-40%                                          | Date: 02-12-2025 |
| Type and Capacity of Extinguisher | : MARQ-6-40%-Kanex ABC Dry Powder Fire Extinguisher Cap. 6 Kg. |                  |
| Batch Number                      | : MARQ40%6 209/25                                              |                  |
| Batch Quantity                    | : 101.00 Nos.                                                  |                  |
| Serial Numbers                    | : 20801 To 20900 And 20805A                                    |                  |
| Month of Manufacturing            | : Dec/25                                                       |                  |

| Sr. Nos.                                                      | Result | Sr. Nos. | Result | Sr. Nos. | Result | Sr. Nos. | Result |
|---------------------------------------------------------------|--------|----------|--------|----------|--------|----------|--------|
| Burst test conducted on 20805A and removed from the Lot/Batch |        |          |        |          |        |          |        |
| 20801                                                         | Pass   | 20802    | Pass   | 20803    | Pass   | 20804    | Pass   |
| 20805                                                         | Pass   | 20806    | Pass   | 20807    | Pass   | 20808    | Pass   |
| 20809                                                         | Pass   | 20810    | Pass   | 20811    | Pass   | 20812    | Pass   |
| 20813                                                         | Pass   | 20814    | Pass   | 20815    | Pass   | 20816    | Pass   |
| 20817                                                         | Pass   | 20818    | Pass   | 20819    | Pass   | 20820    | Pass   |
| 20821                                                         | Pass   | 20822    | Pass   | 20823    | Pass   | 20824    | Pass   |
| 20825                                                         | Pass   | 20826    | Pass   | 20827    | Pass   | 20828    | Pass   |
| 20829                                                         | Pass   | 20830    | Pass   | 20831    | Pass   | 20832    | Pass   |
| 20833                                                         | Pass   | 20834    | Pass   | 20835    | Pass   | 20836    | Pass   |
| 20837                                                         | Pass   | 20838    | Pass   | 20839    | Pass   | 20840    | Pass   |
| 20841                                                         | Pass   | 20842    | Pass   | 20843    | Pass   | 20844    | Pass   |
| 20845                                                         | Pass   | 20846    | Pass   | 20847    | Pass   | 20848    | Pass   |
| 20849                                                         | Pass   | 20850    | Pass   | 20851    | Pass   | 20852    | Pass   |
| 20853                                                         | Pass   | 20854    | Pass   | 20855    | Pass   | 20856    | Pass   |
| 20857                                                         | Pass   | 20858    | Pass   | 20859    | Pass   | 20860    | Pass   |
| 20861                                                         | Pass   | 20862    | Pass   | 20863    | Pass   | 20864    | Pass   |
| 20865                                                         | Pass   | 20866    | Pass   | 20867    | Pass   | 20868    | Pass   |
| 20869                                                         | Pass   | 20870    | Pass   | 20871    | Pass   | 20872    | Pass   |
| 20873                                                         | Pass   | 20874    | Pass   | 20875    | Pass   | 20876    | Pass   |
| 20877                                                         | Pass   | 20878    | Pass   | 20879    | Pass   | 20880    | Pass   |
| 20881                                                         | Pass   | 20882    | Pass   | 20883    | Pass   | 20884    | Pass   |
| 20885                                                         | Pass   | 20886    | Pass   | 20887    | Pass   | 20888    | Pass   |
| 20889                                                         | Pass   | 20890    | Pass   | 20891    | Pass   | 20892    | Pass   |
| 20893                                                         | Pass   | 20894    | Pass   | 20895    | Pass   | 20896    | Pass   |
| 20897                                                         | Pass   | 20898    | Pass   | 20899    | Pass   | 20900    | Pass   |

**Remarks: This is to certify that the above mentioned Fire Extinguishers are tested for hydraulic pressure of 35 bar for 2.5 minute and found satisfactory. No any leakage observed.**



**Authorized Signatory**