

HYDRO PRESSURE TEST

TC No.: HPT/MA6/A40/RQ/211/25	Model No.: MARQ-6-40%	Date: 02-12-2025
Type and Capacity of Extinguisher	: MARQ-6-40%-Kanex ABC Dry Powder Fire Extinguisher Cap. 6 Kg.	
Batch Number	: MARQ40%6 211/25	
Batch Quantity	: 101.00 Nos.	
Serial Numbers	: 21001 To 21100 And 21005A	
Month of Manufacturing	: Dec/25	

Sr. Nos.	Result	Sr. Nos.	Result	Sr. Nos.	Result	Sr. Nos.	Result
Burst test conducted on 21005A and removed from the Lot/Batch							
21001	Pass	21002	Pass	21003	Pass	21004	Pass
21005	Pass	21006	Pass	21007	Pass	21008	Pass
21009	Pass	21010	Pass	21011	Pass	21012	Pass
21013	Pass	21014	Pass	21015	Pass	21016	Pass
21017	Pass	21018	Pass	21019	Pass	21020	Pass
21021	Pass	21022	Pass	21023	Pass	21024	Pass
21025	Pass	21026	Pass	21027	Pass	21028	Pass
21029	Pass	21030	Pass	21031	Pass	21032	Pass
21033	Pass	21034	Pass	21035	Pass	21036	Pass
21037	Pass	21038	Pass	21039	Pass	21040	Pass
21041	Pass	21042	Pass	21043	Pass	21044	Pass
21045	Pass	21046	Pass	21047	Pass	21048	Pass
21049	Pass	21050	Pass	21051	Pass	21052	Pass
21053	Pass	21054	Pass	21055	Pass	21056	Pass
21057	Pass	21058	Pass	21059	Pass	21060	Pass
21061	Pass	21062	Pass	21063	Pass	21064	Pass
21065	Pass	21066	Pass	21067	Pass	21068	Pass
21069	Pass	21070	Pass	21071	Pass	21072	Pass
21073	Pass	21074	Pass	21075	Pass	21076	Pass
21077	Pass	21078	Pass	21079	Pass	21080	Pass
21081	Pass	21082	Pass	21083	Pass	21084	Pass
21085	Pass	21086	Pass	21087	Pass	21088	Pass
21089	Pass	21090	Pass	21091	Pass	21092	Pass
21093	Pass	21094	Pass	21095	Pass	21096	Pass
21097	Pass	21098	Pass	21099	Pass	21100	Pass

Remarks: This is to certify that the above mentioned Fire Extinguishers are tested for hydraulic pressure of 35 bar for 2.5 minute and found satisfactory. No any leakage observed.



Authorized Signatory