

HYDRO PRESSURE TEST

TC No.: HPT/MA6/A40/RQ/355/25	Model No.: MARQ-6-50%	Date: 12-12-2025
Type and Capacity of Extinguisher	: MARQ-6-50%-Kanex ABC Dry Powder Fire Extinguisher Cap. 6 Kg.	
Batch Number	: MARQ50%6 355/25	
Batch Quantity	: 101.00 Nos.	
Serial Numbers	: 35401 To 35500 And 35405A	
Month of Manufacturing	: Dec/25	

Sr. Nos.	Result	Sr. Nos.	Result	Sr. Nos.	Result	Sr. Nos.	Result
Burst test conducted on 35405A and removed from the Lot/Batch							
35401	Pass	35402	Pass	35403	Pass	35404	Pass
35405	Pass	35406	Pass	35407	Pass	35408	Pass
35409	Pass	35410	Pass	35411	Pass	35412	Pass
35413	Pass	35414	Pass	35415	Pass	35416	Pass
35417	Pass	35418	Pass	35419	Pass	35420	Pass
35421	Pass	35422	Pass	35423	Pass	35424	Pass
35425	Pass	35426	Pass	35427	Pass	35428	Pass
35429	Pass	35430	Pass	35431	Pass	35432	Pass
35433	Pass	35434	Pass	35435	Pass	35436	Pass
35437	Pass	35438	Pass	35439	Pass	35440	Pass
35441	Pass	35442	Pass	35443	Pass	35444	Pass
35445	Pass	35446	Pass	35447	Pass	35448	Pass
35449	Pass	35450	Pass	35451	Pass	35452	Pass
35453	Pass	35454	Pass	35455	Pass	35456	Pass
35457	Pass	35458	Pass	35459	Pass	35460	Pass
35461	Pass	35462	Pass	35463	Pass	35464	Pass
35465	Pass	35466	Pass	35467	Pass	35468	Pass
35469	Pass	35470	Pass	35471	Pass	35472	Pass
35473	Pass	35474	Pass	35475	Pass	35476	Pass
35477	Pass	35478	Pass	35479	Pass	35480	Pass
35481	Pass	35482	Pass	35483	Pass	35484	Pass
35485	Pass	35486	Pass	35487	Pass	35488	Pass
35489	Pass	35490	Pass	35491	Pass	35492	Pass
35493	Pass	35494	Pass	35495	Pass	35496	Pass
35497	Pass	35498	Pass	35499	Pass	35500	Pass

Remarks: This is to certify that the above mentioned Fire Extinguishers are tested for hydraulic pressure of 35 bar for 2.5 minute and found satisfactory. No any leakage observed.



Authorized Signatory