

HYDRO PRESSURE TEST

TC No.: HPT/MOD10/CA/RQ/188/25	Model No.: KMCRQ-10	Date: 12-12-2025
Type and Capacity of Extinguisher	: KMCRQ-10-Kanex Clean Agent Modular HFC Based Fire Extinguisher Cap. 10 Kg.	
Batch Number	: KMCRQ10 188/25	
Batch Quantity	: 10.00 Nos.	
Serial Numbers	: 01871 To 1880	
Month of Manufacturing	: Dec/25	

Sr. Nos.	Result	Sr. Nos.	Result	Sr. Nos.	Result	Sr. Nos.	Result
Burst test conducted on 01871 To 1880 and removed from the Lot/Batch							
1871	Pass	1872	Pass	1873	Pass	1874	Pass
1875	Pass	1876	Pass	1877	Pass	1878	Pass
1879	Pass	1880	Pass				

Remarks: This is to certify that the above mentioned Fire Extinguishers are tested for hydraulic pressure of 35 bar for 2.5 minute and found satisfactory. No any leakage observed.



Authorized Signatory