

HYDRO PRESSURE TEST

TC No.: HPT/MOD10/CA/RQ/198/25	Model No.: KMCRQ-10	Date: 23-12-2025
Type and Capacity of Extinguisher	: KMCRQ-10-Kanex Clean Agent Modular HFC Based Fire Extinguisher Cap. 10 Kg.	
Batch Number	: KMCRQ10 198/25	
Batch Quantity	: 10.00 Nos.	
Serial Numbers	: 01971 To 1980	
Month of Manufacturing	: Dec/25	

Sr. Nos.	Result	Sr. Nos.	Result	Sr. Nos.	Result	Sr. Nos.	Result
Burst test conducted on 01971 To 1980 and removed from the Lot/Batch							
1971	Pass	1972	Pass	1973	Pass	1974	Pass
1975	Pass	1976	Pass	1977	Pass	1978	Pass
1979	Pass	1980	Pass				

Remarks: This is to certify that the above mentioned Fire Extinguishers are tested for hydraulic pressure of 35 bar for 2.5 minute and found satisfactory. No any leakage observed.



Authorized Signatory