

# HYDRO PRESSURE TEST

|                                   |                                                                 |                  |
|-----------------------------------|-----------------------------------------------------------------|------------------|
| TC No.: HPT/A2/A90/RQ/028/25      | Model No.: KFARQ-2-90%                                          | Date: 18-04-2025 |
| Type and Capacity of Extinguisher | : KFARQ-2-90%-Kanex ABC Dry Powder Fire Extinguisher Cap. 2 Kg. |                  |
| Batch Number                      | : KFARQ90%2 028/25                                              |                  |
| Batch Quantity                    | : 101.00 Nos.                                                   |                  |
| Serial Numbers                    | : 02701 To 2800 And 2705A                                       |                  |
| Month of Manufacturing            | : Apr/25                                                        |                  |

| Sr. Nos.                                                     | Result | Sr. Nos. | Result | Sr. Nos. | Result | Sr. Nos. | Result |
|--------------------------------------------------------------|--------|----------|--------|----------|--------|----------|--------|
| Burst test conducted on 2705A and removed from the Lot/Batch |        |          |        |          |        |          |        |
| 2701                                                         | Pass   | 2702     | Pass   | 2703     | Pass   | 2704     | Pass   |
| 2705                                                         | Pass   | 2706     | Pass   | 2707     | Pass   | 2708     | Pass   |
| 2709                                                         | Pass   | 2710     | Pass   | 2711     | Pass   | 2712     | Pass   |
| 2713                                                         | Pass   | 2714     | Pass   | 2715     | Pass   | 2716     | Pass   |
| 2717                                                         | Pass   | 2718     | Pass   | 2719     | Pass   | 2720     | Pass   |
| 2721                                                         | Pass   | 2722     | Pass   | 2723     | Pass   | 2724     | Pass   |
| 2725                                                         | Pass   | 2726     | Pass   | 2727     | Pass   | 2728     | Pass   |
| 2729                                                         | Pass   | 2730     | Pass   | 2731     | Pass   | 2732     | Pass   |
| 2733                                                         | Pass   | 2734     | Pass   | 2735     | Pass   | 2736     | Pass   |
| 2737                                                         | Pass   | 2738     | Pass   | 2739     | Pass   | 2740     | Pass   |
| 2741                                                         | Pass   | 2742     | Pass   | 2743     | Pass   | 2744     | Pass   |
| 2745                                                         | Pass   | 2746     | Pass   | 2747     | Pass   | 2748     | Pass   |
| 2749                                                         | Pass   | 2750     | Pass   | 2751     | Pass   | 2752     | Pass   |
| 2753                                                         | Pass   | 2754     | Pass   | 2755     | Pass   | 2756     | Pass   |
| 2757                                                         | Pass   | 2758     | Pass   | 2759     | Pass   | 2760     | Pass   |
| 2761                                                         | Pass   | 2762     | Pass   | 2763     | Pass   | 2764     | Pass   |
| 2765                                                         | Pass   | 2766     | Pass   | 2767     | Pass   | 2768     | Pass   |
| 2769                                                         | Pass   | 2770     | Pass   | 2771     | Pass   | 2772     | Pass   |
| 2773                                                         | Pass   | 2774     | Pass   | 2775     | Pass   | 2776     | Pass   |
| 2777                                                         | Pass   | 2778     | Pass   | 2779     | Pass   | 2780     | Pass   |
| 2781                                                         | Pass   | 2782     | Pass   | 2783     | Pass   | 2784     | Pass   |
| 2785                                                         | Pass   | 2786     | Pass   | 2787     | Pass   | 2788     | Pass   |
| 2789                                                         | Pass   | 2790     | Pass   | 2791     | Pass   | 2792     | Pass   |
| 2793                                                         | Pass   | 2794     | Pass   | 2795     | Pass   | 2796     | Pass   |
| 2797                                                         | Pass   | 2798     | Pass   | 2799     | Pass   | 2800     | Pass   |

**Remarks: This is to certify that the above mentioned Fire Extinguishers are tested for hydraulic pressure of 35 bar for 2.5 minute and found satisfactory. No any leakage observed.**



**Authorized Signatory**